

1 JENNER & BLOCK LLP
 Randy Mehrberg (*pro hac vice*)
 2 RMehrberg@jenner.com
 Reid J. Schar (*pro hac vice*)
 3 RSchar@jenner.com
 4 353 N. Clark Street
 Chicago, IL 60654-3456
 5 Telephone: +1 312 222 9350
 Facsimile: +1 312 527 0484
 6

7 CLARENCE DYER & COHEN LLP
 Kate Dyer (Bar No. 171891)
 8 kdyer@clarencedyer.com
 899 Ellis Street
 9 San Francisco, CA 94109-7807
 Telephone: +1 415 749 1800
 10 Facsimile: +1 415 749 1694

11 Attorneys for Defendant PACIFIC GAS AND ELECTRIC
 12 COMPANY

13 UNITED STATES DISTRICT COURT
 14 NORTHERN DISTRICT OF CALIFORNIA
 15 SAN FRANCISCO DIVISION

16 UNITED STATES OF AMERICA,
 17
 Plaintiff,
 18
 v.
 19
 20 PACIFIC GAS AND ELECTRIC COMPANY,
 21
 Defendant.

Case No. 14-CR-00175-WHA

**RESPONSE TO REQUEST FOR
 CLARIFICATION**

Judge: Hon. William Alsup
 Date: January 17, 2019

22
 23 Pacific Gas and Electric Company (“PG&E”) submits this response to the Court’s Request for
 24 Clarification dated January 15, 2019.

25 The Court ordered PG&E to clarify, with respect to the 2017 Annual Report submitted to the CPUC
 26 pursuant to the CPUC’s Fire Incident Data Collection Plan, which of the incidents listed in the 2017 Annual
 27 Report correspond to the eighteen October 2017 Northern California wildfires that CAL FIRE has
 28

1 attributed to PG&E's facilities. For any of the eighteen October 2017 Northern California wildfires that
2 were not included in the 2017 Annual Report, the Court ordered PG&E to explain why such fires were not
3 included and to compile a list of any other 2017 fires that may have involved PG&E's facilities but were
4 not included in the report.

5 The CPUC's Fire Incident Data Collection Plan requires the reporting of events where utility
6 facilities are associated with: "(a) A self-propagating fire of material other than electrical and/or
7 communication facilities, [where] (b) The resulting fire traveled greater than one linear meter from the
8 ignition point, and (c) The utility has knowledge that the fire occurred". (CPUC Decision 14-02-015
9 at C-3.) The CPUC's decision clarifies that a fire that merely damages utility equipment, rather than one
10 ignited by that equipment, is excluded from the reporting requirement. *Id.* at C-3 n.4. ("Fires that caused
11 damage to utility facilities and whose ignition is not associated with utility facilities are excluded from this
12 reporting requirement.")

13 As PG&E informed the CPUC when it submitted its 2017 Annual Report on March 30, 2018, "Fire
14 incidents that apparently occurred as part of the October 2017 Northern California Wildfires have been
15 excluded from this report where the cause of the ignition is under investigation or may be disputed."
16 PG&E's transmittal to the CPUC is attached to this response as Exhibit A.

17 As a result, seventeen of the eighteen Northern California wildfires that CAL FIRE was then
18 investigating and subsequently attributed to PG&E's facilities were not included in the 2017 Annual
19 Report. One of the eighteen October 2017 Northern California wildfires that CAL FIRE subsequently
20 attributed to PG&E's facilities—the Blue Fire—was included in the 2017 Annual Report at row 412. That
21 fire was included in the Annual Report because the Blue Fire—which occurred in Humboldt County—was
22 outside the geographic perimeter that PG&E used to identify the October 2017 Northern California
23 Wildfires to be excluded from the Annual Report.

24 To prepare the 2017 Annual Report, a team at PG&E reviewed relevant sources of information,
25 such as reports from troublemen responding to incidents, to identify fires that satisfy each of the CPUC
26 reporting requirements. PG&E does not have a complete and accurate catalog of 2017 fires that "may have
27 involved PG&E's facilities" but did not meet CPUC reporting requirements. PG&E does not systemically
28

1 catalog fires that only damaged PG&E's facilities, fires that may have damaged (and thus "involved")
2 PG&E's facilities but were not ignited by PG&E facilities, fires that traveled less than one linear meter
3 from the ignition point, or fires that are not known to PG&E. If the Court wishes PG&E to provide a list
4 of 2017 non-CPUC reportable fires known to PG&E that may have involved PG&E's facilities but that
5 were not ignited by PG&E facilities, damaged only PG&E's own facilities or spread less than a linear
6 meter, it will endeavor to do so, though it may not be possible to compile a complete list of such fires based
7 on available information. Attempting such an undertaking would require considerable effort, and PG&E
8 respectfully would request six to eight weeks to comply with such a request.

9 Respectfully Submitted,

10 Dated: January 17, 2019

JENNER & BLOCK LLP

11
12
13 By: /s/ Reid J. Schar
Randy Mehrberg (*pro hac vice*)
Reid J. Schar (*pro hac vice*)

14
15 CLARENCE DYER & COHEN LLP
16 Kate Dyer (Bar No. 171891)

17
18 Attorneys for Defendant PACIFIC GAS AND
19 ELECTRIC COMPANY

EXHIBIT A

From: Pazdan, Kenneth
Sent: Friday, March 30, 2018 3:05 PM
To: 'Elizaveta.Malashenko@cpuc.ca.gov'
Cc: leslie.palmer@cpuc.ca.gov; Charlotte.terkeurst@cpuc.ca.gov; Koko Tomassian; McFarren, Dean; Dasso, Kevin; Allen, Meredith
Subject: PG&E's 2017 annual report for the fire incident data collection plan

Dear Ms. Malashenko,

In accordance with Decision 14-02-015, PG&E submits its Fire Incident Data Collection Plan annual report for 2017.

Fire incidents that apparently occurred as part of the October 2017 Northern California Wildfires have been excluded from this report where the cause of the ignition is under investigation or may be disputed.

Thank you,
Kenneth Pazdan
Director, Compliance and Quality Management



PGE Fire Incident Data Collection annual report for 2017-SED.xlsx

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
3	PG&E	01/01/17	15:57	38.66287	-121.74803	Vegetation	Urban	< 3 Meters	Fire Agency	Woodland fire dept 530-666-8920	101589774	Unknown	0 – 750	Conductor	Overhead
4	PG&E	01/10/17	15:55	38.75380	-121.15641	Building	Urban	Structure Only	Unknown	N.A.	100065079	Unknown	12,000	Conductor	Overhead
5	PG&E	01/18/17	15:34	37.38388	-121.80884	Building	Urban	Structure Only	Unknown	N.A.	100564835	PACIFIC BELL	0 – 750	Conductor	Overhead
6	PG&E	01/29/17	09:45	38.36159	-121.95091	Building	Urban	Structure Only	Fire Agency	Unknown	T8550	Unknown	12,000	Transformer	Subsurface
7	PG&E	02/03/17	10:00	37.56153	-122.02772	Vegetation	Urban	< 3 Meters	Fire Agency	jeff	100938466	Unknown	12,000	Conductor	Overhead
8	PG&E	02/07/17	04:50	38.43314	-122.71902	Building	Urban	Structure Only	Fire Agency	Santa Rosa Fire Dept	102014637	PACIFIC BELL	12,000	Conductor	Overhead
9	PG&E	03/16/17	12:43	38.27175	-122.01971	Other	Urban	< 0.25 Acres	Fire Agency	Unknown	101561532	PACIFIC BELL	12,000	Conductor	Overhead
10	PG&E	03/17/17	09:37	38.11532	-121.42216	Other	Rural	Structure Only	Fire Agency	911	102044732	PACIFIC BELL	21,000	Conductor	Overhead
11	PG&E	03/19/17	17:06	39.76209	-121.85247	Vegetation	Urban	< 3 Meters	Fire Agency	CHICO FIRE DEPT 911	100441377	PACIFIC BELL	0 – 750	Conductor	Overhead
12	PG&E	03/23/17	07:04	37.36975	-121.85218	Other	Urban	< 3 Meters	Fire Agency	SJFD disp 408-277-8950 Incident# F170829041	103485262	Unknown	12,000	Transformer	Subsurface
13	PG&E	03/28/17	12:15	34.88092	-120.41992	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	103397961	YES	12,000	Conductor	Overhead
14	PG&E	04/01/17	14:54	37.18823	-120.95764	Vegetation	Rural	< 0.25 Acres	Fire Agency	engine 74 mrced fire agency	102318665	Unknown	12,000	Conductor	Overhead
15	PG&E	04/04/17	13:29	35.68851	-120.76533	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101945026	None	12,000	Conductor	Overhead
16	PG&E	04/04/17	14:54	37.29584	-121.93295	Vegetation	Urban	< 3 Meters	Customer	N.A.	100591136	None	12,000	Conductor	Overhead
17	PG&E	04/10/17	16:35	35.61751	-119.74296	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100128630	Unknown	21,000	Conductor	Overhead
18	PG&E	04/13/17	14:21	37.79671	-121.25210	Other	Urban	Structure Only	Fire Agency	MANTECA CITY	102104500	VERIZON CALIFO	17,000	Conductor	Overhead
19	PG&E	04/16/17	15:14	35.58053	-119.14227	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103833904	Unknown	12,000	Conductor	Overhead
20	PG&E	04/20/17	20:14	37.37407	-120.71688	Vegetation	Urban	< 3 Meters	Fire Agency	209-966-3621	101205903	Unknown	12,000	Transformer	Overhead
21	PG&E	04/23/17	7:10	36.07345	-120.93450	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101726333	Unknown	12,000	Conductor	Overhead
22	PG&E	04/24/17	11:52	36.18990	-121.15129	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101718856	None	12,000	Conductor	Overhead
23	PG&E	04/25/17	12:38	38.65832	-120.97622	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101376746	Unknown	0 – 750	Transformer	Overhead
24	PG&E	04/25/17	18:26	36.23725	-119.78071	Other	Rural	Structure Only	Self Extinguished	N.A.	100716676	Unknown	0 – 750	Conductor	Overhead
25	PG&E	04/26/17	15:55	38.15608	-121.67886	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT KENNY WILLIAMS (707)374-2233	103826165	Unknown	21,000	Conductor	Overhead
26	PG&E	04/28/17	5:55	34.58848	-120.10568	Vegetation	Rural	< 0.25 Acres	Fire Agency	805-683-2724	101900122	Unknown	12,000	Conductor	Overhead
27	PG&E	04/28/17	14:35	37.12469	-121.62488	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	103098414	Unknown	0 – 750	Conductor	Overhead
28	PG&E	04/28/17	15:49	38.76786	-120.96253	Vegetation	Rural	< 0.25 Acres	Fire Agency	chris paper fire investigator, 530/677-1868. incident #caaeuo11821	101409833	PACIFIC BELL	21,000	Conductor	Overhead
29	PG&E	04/29/17	15:07	37.03486	-119.52423	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100678661	Unknown	12,000	Conductor	Overhead
30	PG&E	04/30/17	9:32	35.63491	-118.95629	Vegetation	Rural	< 0.25 Acres	Fire Agency	661-324-6551	100216308	Unknown	21,000	Conductor	Overhead
31	PG&E	05/01/17	14:20	36.02269	-119.95837	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CORCORAN STATION 559- 992-2156	Pole 076/015	Unknown	70,000	Conductor	Overhead
32	PG&E	05/03/17	10:04	36.81613	-119.63202	Vegetation	Rural	< 0.25 Acres	Fire Agency	eng 44 Eric connors 559-324- 2294	100770906	PACIFIC BELL	12,000	Conductor	Overhead
33	PG&E	05/03/17	12:51	38.19080	-121.66150	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834798	None	21,000	Conductor	Overhead
34	PG&E	05/04/17	16:19	35.55728	-120.75348	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101934476	Unknown	21,000	Conductor	Overhead
35	PG&E	05/05/17	15:52	40.37758	-123.00187	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101501566	None	12,000	Conductor	Overhead
36	PG&E	05/06/17	1:56	37.32997	-120.83297	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834182	Unknown	12,000	Conductor	Overhead
37	PG&E	05/06/17	11:18	40.79512	-124.02902	Vegetation	Rural	< 3 Meters	Fire Agency	chief rick harden 7074423352	103661154	Unknown	12,000	Conductor	Overhead
38	PG&E	05/06/17	12:43	40.76227	-124.16195	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100998152	Unknown	12,000	Conductor	Overhead
39	PG&E	05/06/17	15:00	39.24580	-123.77854	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	102185559	Unknown	12,000	Conductor	Overhead
40	PG&E	05/06/17	23:46	36.16537	-120.37372	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100741510	PACIFIC BELL	12,000	Conductor	Overhead
41	PG&E	05/09/17	11:15	40.05970	-122.18895	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101531151	PACIFIC BELL	12,000	Conductor	Overhead
42	PG&E	05/09/17	15:57	39.54650	-121.85667	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100404826	Unknown	12,000	Conductor	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
43	PG&E	05/09/17	18:26	40.86892	-123.51559	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	todd wright fire chief. 5307392493	103796045	Unknown	12,000	Conductor	Overhead
44	PG&E	05/12/17	15:16	38.85066	-121.31683	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102347828	Unknown	21,000	Conductor	Overhead
45	PG&E	05/13/17	21:49	39.67845	-121.77802	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	100355502	Unknown	12,000	Conductor	Overhead
46	PG&E	05/14/17	11:59	38.07980	-122.86650	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102247059	PACIFIC BELL	12,000	Conductor	Overhead
47	PG&E	05/14/17	16:09	35.60167	-119.65665	Vegetation	Rural	10 - 99 Acres	Fire Agency	661-391-7000	100131572	Unknown	21,000	Conductor	Overhead
48	PG&E	05/15/17	3:05	35.62610	-120.89616	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101873299	Unknown	21,000	Conductor	Overhead
49	PG&E	05/15/17	13:05	38.19694	-121.40951	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102071491	Unknown	12,000	Transformer	Overhead
50	PG&E	05/15/17	16:00	37.17665	-119.81887	Vegetation	Rural	< 0.25 Acres	Fire Agency	SHAUN FAIRBANKS 559-683-4823	101108423	SIERRA	21,000	Conductor	Overhead
51	PG&E	05/15/17	20:57	38.67253	-122.04559	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101589358	Unknown	21,000	Conductor	Overhead
52	PG&E	05/16/17	17:21	35.37590	-119.14413	Vegetation	Urban	< 0.25 Acres	Fire Agency	324-6551	103264300	Unknown	12,000	Conductor	Overhead
53	PG&E	05/17/17	14:49	37.22500	-120.48326	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101154662	Unknown	12,000	Transformer	Overhead
54	PG&E	05/17/17	15:13	36.24862	-121.03830	Other	Rural	10 - 99 Acres	Fire Agency	Unknown	101764465	None	12,000	Conductor	Overhead
55	PG&E	05/19/17	9:37	40.03343	-122.09887	Vegetation	Rural	< 0.25 Acres	Fire Agency	INCIDENT NUMBER 004751	101534483	Unknown	0 - 750	Conductor	Overhead
56	PG&E	05/19/17	10:52	37.20861	-121.09683	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 044/004	Unknown	115,000	Conductor	Overhead
57	PG&E	05/20/17	12:20	36.65278	-119.80121	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100649202	Unknown	0 - 750	Conductor	Overhead
58	PG&E	05/21/17	11:36	39.42773	-121.69795	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100379216	Unknown	12,000	Conductor	Overhead
59	PG&E	05/21/17	22:47	38.06453	-122.56982	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102238142	PACIFIC BELL	12,000	Transformer	Overhead
60	PG&E	05/22/17	5:39	36.37529	-121.04797	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101770874	Unknown	21,000	Other	Overhead
61	PG&E	05/22/17	17:52	37.75450	-121.41930	Vegetation	Urban	< 0.25 Acres	Fire Agency	TRACY	102119359	Unknown	12,000	Conductor	Overhead
62	PG&E	05/24/17	16:24	38.83404	-121.11965	Vegetation	Rural	< 3 Meters	Fire Agency	Fire Capt	103838109	None	12,000	Conductor	Overhead
63	PG&E	05/25/17	11:09	37.45264	-121.88900	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	ERIC EMMANUELE OFFICE (408)586-3365 DIRECT (408)586-3383	100557380	Unknown	12,000	Transformer	Overhead
64	PG&E	05/25/17	15:05	36.52168	-121.84729	Vegetation	Rural	< 0.25 Acres	Fire Agency	Buddy Bloxham 831-236-5659	101778611	PACIFIC BELL	12,000	Conductor	Overhead
65	PG&E	05/25/17	16:55	38.39860	-122.98760	Vegetation	Rural	< 3 Meters	Utility: PG&E	N.A.	101974034	Unknown	12,000	Conductor	Overhead
66	PG&E	05/29/17	18:29	39.22451	-121.37525	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101304842	PACIFIC BELL	12,000	Conductor	Overhead
67	PG&E	05/30/17	11:40	36.80045	-121.77018	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101707398	Unknown	12,000	Conductor	Overhead
68	PG&E	05/31/17	2:06	38.75403	-121.22378	Vegetation	Rural	< 0.25 Acres	Fire Agency	Placer Co. fire	100063341	ROSEVILLE	12,000	Conductor	Overhead
69	PG&E	05/31/17	5:24	37.02750	-120.07067	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101113852	Unknown	12,000	Conductor	Overhead
70	PG&E	06/01/17	9:11	40.18301	-122.26654	Vegetation	Rural	< 0.25 Acres	Fire Agency	MARK FRITZ	101546068	Unknown	12,000	Conductor	Overhead
71	PG&E	06/01/17	21:35	41.05570	-121.38690	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101550337	FRONTIER COMM	12,000	Conductor	Overhead
72	PG&E	06/01/17	22:14	36.65394	-121.62918	Vegetation	Rural	< 3 Meters	Fire Agency	Salinas FD	101732390	Unknown	12,000	Lightning Arrestor	Overhead
73	PG&E	06/03/17	13:26	38.90174	-121.20559	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100043664	PACIFIC BELL	12,000	Conductor	Overhead
74	PG&E	06/03/17	20:52	36.83229	-119.63327	Vegetation	Rural	< 3 Meters	Fire Agency	CLOVIS F.D. CHIEF	100768082	Unknown	12,000	Conductor	Overhead
75	PG&E	06/04/17	00:08	36.98200	-120.03471	Vegetation	Rural	< 0.25 Acres	Fire Agency	Mike Gomez 559 906-1621 Incident #17cammu011185	103837406	None	12,000	Conductor	Overhead
76	PG&E	06/04/17	13:12	36.74591	-120.06018	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100645872	Unknown	12,000	Conductor	Overhead
77	PG&E	06/05/17	0:52	38.23420	-121.21311	Vegetation	Rural	< 3 Meters	Unknown	N.A.	102083982	PACIFIC BELL	12,000	Transformer	Overhead
78	PG&E	06/05/17	7:56	37.85680	-120.88150	Vegetation	Rural	< 0.25 Acres	Fire Agency	209 5523911	102333651	None	17,000	Conductor	Overhead
79	PG&E	06/05/17	17:12	36.94243	-121.46123	Vegetation	Rural	10 - 99 Acres	Fire Agency	Leo Alvarez 831-6364324	101717332	Unknown	21,000	Conductor	Overhead
80	PG&E	06/06/17	9:15	36.45426	-119.13382	Vegetation	Rural	< 0.25 Acres	Fire Agency	TIM ROGERS, 559-358-7120	102306658	Unknown	12,000	Conductor	Overhead
81	PG&E	06/06/17	09:48	36.99857	-120.93690	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	101199765	Unknown	12,000	Conductor	Overhead
82	PG&E	06/06/17	13:39	38.17110	-121.67825	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101666656	FRONTIER COMM	21,000	Fuse	Overhead
83	PG&E	06/07/17	13:25	35.09398	-119.41607	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100192567	Unknown	12,000	Conductor	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
2	Utility Name	Fire Start		Location				Fire			Utility Facility				
		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
84	PG&E	06/07/17	10:13	39.56030	-122.10768	Vegetation	Rural	< 3 Meters	Utility: PG&E	N.A.	103838281	Unknown	12,000	Conductor	Overhead
85	PG&E	06/08/17	5:33	36.23884	-120.30164	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	100743822	Unknown	12,000	Conductor	Overhead
86	PG&E	06/08/17	0:26	37.12759	-120.01930	Vegetation	Rural	100 - 299 Acres	Fire Agency	Jeff Mc Carroll (559) 806 - 8815	103205823	Unknown	12,000	Conductor	Overhead
87	PG&E	06/08/17	15:08	34.60580	-120.02140	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SHAWN STEINER	101947678	Unknown	12,000	Conductor	Overhead
88	PG&E	06/09/17	10:40	36.69563	-119.71863	Vegetation	Rural	< 0.25 Acres	Fire Agency	FRESNO COUNTY	100793555	Unknown	12,000	Conductor	Overhead
89	PG&E	06/09/17	13:27	36.73820	-119.82038	Vegetation	Rural	< 0.25 Acres	Fire Agency	FFD INC # 703 4018	100895732	Unknown	12,000	Conductor	Overhead
90	PG&E	06/09/17	17:20	35.79741	-120.53892	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	103406061	Unknown	12,000	Conductor	Overhead
91	PG&E	06/10/17	07:37	35.43590	-120.49570	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101890429	Unknown	21,000	Conductor	Overhead
92	PG&E	06/12/17	15:28	36.96720	-120.09309	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101136946	Unknown	12,000	Conductor	Overhead
93	PG&E	06/12/17	18:04	35.36381	-118.82556	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	103371824	Unknown	12,000	Transformer	Overhead
94	PG&E	06/13/17	14:30	37.85265	-122.18529	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	Tower 005/035c	Unknown	115,000	Conductor	Overhead
95	PG&E	06/14/17	22:23	39.75591	-121.59343	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100324481	PACIFIC BELL	12,000	Fuse	Overhead
96	PG&E	06/15/17	2:58	40.29899	-122.43185	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101511631	PACIFIC BELL	12,000	Conductor	Overhead
97	PG&E	06/15/17	5:02	36.82613	-121.67456	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101712958	PACIFIC BELL	12,000	Conductor	Overhead
98	PG&E	06/15/17	7:39	39.22756	-121.23476	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE CHIEF	103676075	Unknown	21,000	Conductor	Overhead
99	PG&E	06/15/17	15:01	39.39127	-123.30541	Vegetation	Rural	< 0.25 Acres	Fire Agency	STEPHEN	103838176	YES	12,000	Conductor	Overhead
100	PG&E	06/15/17	16:21	38.70880	-122.90160	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101957366	Unknown	0 - 750	Conductor	Overhead
101	PG&E	06/15/17	17:18	38.79696	-121.20690	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	100058437	Unknown	21,000	Conductor	Overhead
102	PG&E	06/16/17	13:50	35.45050	-120.61690	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101889864	Unknown	21,000	Conductor	Overhead
103	PG&E	06/16/17	14:22	36.84496	-120.01918	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	101212782	Unknown	0 - 750	Conductor	Overhead
104	PG&E	06/16/17	16:17	39.22260	-121.00411	Vegetation	Rural	< 3 Meters	Fire Agency	GVFIRE	100036908	Unknown	12,000	Conductor	Overhead
105	PG&E	06/16/17	17:59	37.30938	-122.04719	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100555441	PACIFIC BELL	0 - 750	Conductor	Overhead
106	PG&E	06/16/17	19:14	38.34429	-122.78122	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101970801	Unknown	0 - 750	Conductor	Overhead
107	PG&E	06/16/17	22:30	38.03734	-122.18465	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101424286	Unknown	21,000	Conductor	Overhead
108	PG&E	06/17/17	02:53	37.33567	-120.58295	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101147424	Unknown	12,000	Conductor	Overhead
109	PG&E	06/17/17	15:49	36.93896	-119.68463	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103406061	Unknown	21,000	Conductor	Overhead
110	PG&E	06/18/17	23:49	39.19494	-122.96321	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102160857	Unknown	12,000	Conductor	Overhead
111	PG&E	06/18/17	12:22	36.72578	-119.79068	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100894729	PACIFIC BELL	0 - 750	Conductor	Overhead
112	PG&E	06/18/17	13:10	38.23703	-122.67015	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102007208	PACIFIC BELL	12,000	Conductor	Overhead
113	PG&E	06/18/17	18:09	37.55165	-122.29253	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100309893	Unknown	21,000	Conductor	Overhead
114	PG&E	06/18/17	20:16	38.88844	-122.02044	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101650987	None	12,000	Lightning Arrestor	Overhead
115	PG&E	06/18/17	21:07	37.83974	-121.28643	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102085809	Unknown	12,000	Conductor	Overhead
116	PG&E	06/18/17	22:12	38.53900	-122.79203	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	102029435	Unknown	12,000	Other	Overhead
117	PG&E	06/18/17	23:12	36.75747	-119.66455	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100780126	PACIFIC BELL	12,000	Conductor	Overhead
118	PG&E	06/18/17	23:31	38.89731	-121.29467	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103782395	Unknown	12,000	Conductor	Overhead
119	PG&E	06/19/17	01:23	35.36762	-118.95521	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100252360	PACIFIC BELL	21,000	Conductor	Overhead
120	PG&E	06/19/17	13:51	39.90633	-122.17660	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103841797	YES	12,000	Conductor	Overhead
121	PG&E	06/19/17	16:18	37.79272	-121.23058	Other	Urban	Structure Only	Utility: PG&E	N.A.	103582825	Unknown	17,000	Transformer	Subsurface
122	PG&E	06/19/17	16:26	37.93783	-120.60897	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101282825	Unknown	17,000	Other	Overhead
123	PG&E	06/19/17	17:31	36.76268	-120.37580	Vegetation	Rural	< 3 Meters	Unknown	N.A.	101094343	Unknown	12,000	Transformer	Overhead
124	PG&E	06/19/17	18:00	38.45496	-121.82416	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101594910	PACIFIC BELL	12,000	Lightning Arrestor	Overhead
125	PG&E	06/19/17	20:22	38.10123	-120.86969	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101233468	Unknown	12,000	Transformer	Overhead
126	PG&E	06/20/17	00:49	39.74900	-121.89975	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100437523	PACIFIC BELL	12,000	Conductor	Overhead
127	PG&E	06/20/17	09:12	39.19754	-121.49499	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101306700	Unknown	12,000	Conductor	Overhead
128	PG&E	06/20/17	10:08	39.03668	-121.07630	Vegetation	Urban	< 3 Meters	Fire Agency	JERRY GOOD 530 268-0844	100023174	None	12,000	Conductor	Overhead
129	PG&E	06/20/17	13:37	37.92473	-122.08954	Vegetation	Urban	< 3 Meters	Fire Agency	contra costa fire	100476159	PACIFIC BELL	12,000	Capacitor Bank	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
130	PG&E	06/20/17	15:17	40.11262	-123.76774	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100987107	Unknown	12,000	Conductor	Overhead
131	PG&E	06/20/17	11:51	40.31556	-124.06111	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101006039	Unknown	12,000	Conductor	Overhead
132	PG&E	06/20/17	18:32	37.92810	-121.23323	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102132644	Unknown	12,000	Conductor	Overhead
133	PG&E	06/20/17	20:46	38.90764	-121.26030	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100085621	PACIFIC BELL	12,000	Conductor	Overhead
134	PG&E	06/20/17	23:16	35.63750	-120.85660	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101873622	Unknown	12,000	Conductor	Overhead
135	PG&E	06/21/17	08:41	39.16997	-122.15731	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101637081	Unknown	12,000	Conductor	Overhead
136	PG&E	06/21/17	14:23	38.99208	-121.35362	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100027499	PACIFIC BELL	12,000	Transformer	Overhead
137	PG&E	06/22/17	9:36	38.39647	-120.47274	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101251777	Unknown	12,000	Conductor	Overhead
138	PG&E	06/22/17	16:30	39.61307	-121.68724	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100347529	None	12,000	Conductor	Overhead
139	PG&E	06/22/17	18:07	38.75831	-120.71764	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101401088	Unknown	12,000	Conductor	Overhead
140	PG&E	06/22/17	19:29	35.58886	-120.66910	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101912249	Unknown	21,000	Conductor	Overhead
141	PG&E	06/23/17	13:00	39.30510	-122.48618	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	100329817	Unknown	0 - 750	Conductor	Overhead
142	PG&E	06/23/17	20:09	40.38565	-122.28408	Vegetation	Urban	< 0.25 Acres	Fire Agency	kieth foster 530-347-4737	101505644	Unknown	12,000	Conductor	Overhead
143	PG&E	06/23/17	19:23	39.78294	-121.86700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100397376	None	12,000	Conductor	Overhead
144	PG&E	06/24/17	10:31	38.94379	-121.04466	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100090318	PACIFIC BELL	12,000	Transformer	Overhead
145	PG&E	06/24/17	14:51	38.36218	-120.76381	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101255656	Unknown	12,000	Fuse	Overhead
146	PG&E	06/24/17	22:27	38.29083	-120.84900	Vegetation	Rural	10 - 99 Acres	Fire Agency	CONTACT BOBBY BOWMAN	101238865	None	12,000	Conductor	Overhead
147	PG&E	06/25/17	18:18	37.32357	-120.55914	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101159230	Unknown	12,000	Conductor	Overhead
148	PG&E	06/25/17	0:23	39.40434	-123.38687	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	102193088	PACIFIC BELL	12,000	Conductor	Overhead
149	PG&E	06/25/17	6:02	39.07743	-121.52937	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101314125	Unknown	12,000	Conductor	Overhead
150	PG&E	06/25/17	15:37	34.93950	-119.69246	Vegetation	Rural	100 - 299 Acres	Fire Agency	805-686-5074	100191652	None	12,000	Conductor	Overhead
151	PG&E	06/25/17	22:14	39.02503	-121.57873	Vegetation	Rural	< 3 Meters	Fire Agency	Olivehurst FD	101314072	Unknown	21,000	Conductor	Overhead
152	PG&E	06/26/17	8:18	37.27331	-120.52573	Vegetation	Rural	< 0.25 Acres	Self Extinguished	N.A.	103218794	Unknown	12,000	Conductor	Overhead
153	PG&E	06/26/17	14:29	35.97817	-120.11694	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	HENNAGIN 559 386 555	103243976	Unknown	21,000	Conductor	Overhead
154	PG&E	06/27/17	9:23	37.95588	-122.61762	Vegetation	Rural	10 - 99 Acres	Fire Agency	marin county fire	102260068	UNFILED	12,000	Conductor	Overhead
155	PG&E	06/27/17	17:47	39.51264	-122.20333	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100341056	None	21,000	Conductor	Overhead
156	PG&E	06/28/17	09:57	35.90555	-120.84214	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	101765453	Unknown	12,000	Conductor	Overhead
157	PG&E	06/28/17	13:09	34.92757	-119.62041	Building	Rural	Structure Only	Fire Agency	(805)683-2724)	100190548	Unknown	21,000	Conductor	Overhead
158	PG&E	06/29/17	18:31	38.44450	-122.89990	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102021185	PACIFIC BELL	0 - 750	Conductor	Overhead
159	PG&E	06/29/17	21:55	35.98040	-121.09557	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	103312369	Unknown	12,000	Transformer	Overhead
160	PG&E	06/30/17	10:24	39.02621	-121.54317	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101341770	Unknown	21,000	Conductor	Overhead
161	PG&E	06/30/17	01:20	39.82098	-121.58834	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103840463	YES	12,000	Conductor	Overhead
162	PG&E	06/30/17	23:54	38.57941	-122.88349	Vegetation	Rural	< 3 Meters	Customer	N.A.	101958804	PACIFIC BELL	12,000	Conductor	Overhead
163	PG&E	07/01/17	12:02	39.82093	-121.64183	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	Pole 003/039	Unknown	60,000	Conductor	Overhead
164	PG&E	07/01/17	3:54	36.99950	-119.97648	Vegetation	Rural	< 0.25 Acres	Fire Agency	2099663621	101015895	Unknown	0 - 750	Conductor	Overhead
165	PG&E	07/01/17	3:12	38.19517	-122.91971	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103855493	Unknown	12,000	Conductor	Overhead
166	PG&E	07/01/17	10:41	39.27788	-121.68748	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101294919	Unknown	12,000	Other	Overhead
167	PG&E	07/02/17	13:28	39.86055	-121.62736	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 000/017c	Unknown	60,000	Conductor	Overhead
168	PG&E	07/02/17	3:49	36.95878	-120.89268	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101205043	Unknown	12,000	Conductor	Overhead
169	PG&E	07/03/17	20:26	38.79229	-120.94384	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101388730	PACIFIC BELL	21,000	Conductor	Overhead
170	PG&E	07/04/17	13:56	40.38303	-122.31503	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101506140	PACIFIC BELL	12,000	Conductor	Overhead
171	PG&E	07/04/17	16:16	38.87628	-121.13185	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100050181	PACIFIC BELL	0 - 750	Conductor	Overhead
172	PG&E	07/04/17	20:16	40.42283	-122.39748	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SCOTT CORN 530-448-2414	101481860	Unknown	0 - 750	Conductor	Overhead
173	PG&E	07/05/17	3:25	38.68451	-121.01176	Vegetation	Urban	< 0.25 Acres	Fire Agency	JUSTIN RHAMES	101380157	PACIFIC BELL	21,000	Fuse	Overhead
174	PG&E	07/05/17	11:58	39.21046	-121.22662	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	STEVE ROBERTSON 530 906 4892	100010286	Unknown	21,000	Conductor	Overhead
175	PG&E	07/05/17	20:54	35.68475	-120.10996	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	661-324-6551 LOG325962	100171224	Unknown	21,000	Capacitor Bank	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
176	PG&E	07/06/17	15:18	36.74020	-119.76128	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100864107	PACIFIC BELL	0 – 750	Conductor	Overhead
177	PG&E	07/06/17	14:02	39.30091	-122.51726	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100414219	Unknown	12,000	Conductor	Overhead
178	PG&E	07/06/17	20:07	39.59874	-121.90988	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100436921	None	12,000	Conductor	Overhead
179	PG&E	07/06/17	23:30	35.55618	-120.75520	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101934472	Unknown	21,000	Conductor	Overhead
180	PG&E	07/07/17	15:09	40.90536	-122.38061	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	101455950	Unknown	12,000	Conductor	Overhead
181	PG&E	07/07/17	14:31	37.49900	-119.79900	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	STEVEN WARD OFFICE 209-966-3542 CELL559-706-8811	103855637	Unknown	21,000	Conductor	Overhead
182	PG&E	07/08/17	4:03	38.55354	-121.53680	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101584938	Unknown	0 – 750	Conductor	Overhead
183	PG&E	07/08/17	15:59	37.28217	-122.01887	Other	Urban	< 0.25 Acres	Fire Agency	Unknown	100540958	Unknown	0 – 750	Conductor	Overhead
184	PG&E	07/08/17	18:16	35.46529	-120.67132	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	103392970	Unknown	0 – 750	Conductor	Overhead
185	PG&E	07/08/17	18:49	40.29354	-122.40890	Vegetation	Rural	10 - 99 Acres	Fire Agency	TOM STROING, RED BLUFF	101526269	PACIFIC BELL	12,000	Conductor	Overhead
186	PG&E	07/09/17	7:07	36.50920	-121.44651	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103011964	Unknown	12,000	Conductor	Overhead
187	PG&E	07/09/17	11:00	39.42015	-121.54390	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100394209	PACIFIC BELL	12,000	Conductor	Overhead
188	PG&E	07/10/17	09:07	38.20742	-121.23350	Vegetation	Rural	< 3 Meters	Customer	N.A.	102083900	Unknown	0 – 750	Conductor	Overhead
189	PG&E	07/10/17	12:32	40.26028	-123.82528	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103139646	Unknown	12,000	Conductor	Overhead
190	PG&E	07/10/17	16:39	36.96201	-120.85839	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	EFRAIN CHAVARRIA	101203174	Unknown	12,000	Conductor	Overhead
191	PG&E	07/10/17	17:00	37.37677	-122.35967	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	David Hibdon 831-254-1763	100270370	Unknown	12,000	Conductor	Overhead
192	PG&E	07/11/17	8:11	38.13370	-121.10542	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102072316	None	21,000	Other	Overhead
193	PG&E	07/11/17	11:53	38.03382	-121.32243	Vegetation	Urban	< 0.25 Acres	Utility: PG&E	N.A.	102118581	PACIFIC BELL	0 – 750	Conductor	Overhead
194	PG&E	07/11/17	13:56	39.45061	-121.71535	Vegetation	Rural	< 0.25 Acres	Fire Agency	chip fowler	100423597	Unknown	0 – 750	Conductor	Overhead
195	PG&E	07/11/17	22:12	37.01217	-121.94972	Vegetation	Rural	< 3 Meters	Fire Agency	CAPT PHIL CRAMBLET 831-479-6842	101676689	PACIFIC BELL	21,000	Conductor	Overhead
196	PG&E	07/12/17	16:04	40.65308	-122.33429	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	Structure 000/001	Unknown	60,000	Conductor	Overhead
197	PG&E	07/12/17	05:51	38.39320	-121.80440	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101584920	Unknown	12,000	Conductor	Overhead
198	PG&E	07/12/17	10:48	36.96254	-120.04632	Other	Urban	< 0.25 Acres	Fire Agency	Barbera Riley 661-5499 ext. 2	103222654	None	0 – 750	Conductor	Overhead
199	PG&E	07/12/17	15:09	37.14908	-122.00371	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	103565794	Unknown	21,000	Conductor	Overhead
200	PG&E	07/12/17	20:21	40.08083	-123.83389	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103841917	Unknown	12,000	Conductor	Overhead
201	PG&E	07/13/17	5:13	38.12011	-122.18577	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Tower 025/173	Unknown	115,000	Conductor	Overhead
202	PG&E	07/13/17	07:43	39.40638	-122.12630	Vegetation	Rural	< 3 Meters	Fire Agency	AXS-N/A FIRE NEAR POLE PER FD. NO STDBY. WANT CHECK OF POLE 530-458-0200	100406386	None	0 – 750	Conductor	Overhead
203	PG&E	07/13/17	19:29	36.85038	-119.54996	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	chis waters bat.chief 559-281-4308	100728986	Unknown	0 – 750	Conductor	Overhead
204	PG&E	07/14/17	17:54	37.70950	-121.29210	Vegetation	Rural	< 0.25 Acres	Fire Agency	TRACY	102070196	Unknown	12,000	Conductor	Overhead
205	PG&E	07/15/17	14:34	39.62313	-121.53281	Vegetation	Rural	< 0.25 Acres	Fire Agency	russ fowler	100404385	Unknown	12,000	Conductor	Overhead
206	PG&E	07/15/17	14:56	37.30740	-122.03550	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100538519	PACIFIC BELL	0 – 750	Conductor	Overhead
207	PG&E	07/15/17	20:16	39.45902	-121.53134	Vegetation	Rural	< 3 Meters	Fire Agency	oroville station	100429093	Unknown	12,000	Conductor	Overhead
208	PG&E	07/15/17	21:01	38.21284	-121.83399	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101658237	Unknown	21,000	Conductor	Overhead
209	PG&E	07/16/17	10:39	40.34139	-123.87861	Vegetation	Rural	< 3 Meters	Fire Agency	707-726-1280	100990019	Unknown	12,000	Conductor	Overhead
210	PG&E	07/16/17	11:59	36.66692	-121.75148	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101761892	None	21,000	Fuse	Overhead
211	PG&E	07/16/17	12:10	35.66129	-120.92200	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101942626	Unknown	21,000	Conductor	Overhead
212	PG&E	07/16/17	17:07	37.34415	-122.03630	Vegetation	Urban	< 3 Meters	Fire Agency	sunnyvale fire	100532224	PACIFIC BELL	0 – 750	Transformer	Overhead
213	PG&E	07/17/17	07:39	40.16532	-122.22279	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101543808	PACIFIC BELL	12,000	Conductor	Overhead
214	PG&E	07/17/17	10:00	35.95605	-120.85152	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101765495	Unknown	12,000	Conductor	Overhead
215	PG&E	07/17/17	18:58	38.88853	-121.98984	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Dunnigan Fire Dept	101602915	PACIFIC BELL	12,000	Conductor	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
216	PG&E	07/18/17	11:30	38.04843	-120.55653	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	Structure 012/071	Unknown	115,000	Conductor	Overhead
217	PG&E	07/18/17	21:40	38.00311	-122.20926	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	Pole 000/002 to 000/003	Unknown	60,000	Conductor	Overhead
218	PG&E	07/18/17	07:39	38.07038	-120.54518	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101269434	Unknown	0 – 750	Other	Overhead
219	PG&E	07/18/17	11:45	36.83081	-119.86228	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100624764	PACIFIC BELL	21,000	Capacitor Bank	Overhead
220	PG&E	07/19/17	5:52	37.09047	-119.60469	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Tower 003/001	Unknown	115,000	Conductor	Overhead
221	PG&E	07/19/17	09:33	35.34462	-118.86086	Vegetation	Rural	< 3 Meters	Unknown	N.A.	100159158	Unknown	12,000	Capacitor Bank	Overhead
222	PG&E	07/19/17	17:19	39.41242	-123.81234	Vegetation	Rural	< 0.25 Acres	Fire Agency	DRUE RHOADS 707 964 5673	102201550	YES	12,000	Conductor	Overhead
223	PG&E	07/20/17	20:57	37.73609	-122.49208	Building	Urban	Structure Only	Unknown	N.A.	101813719	Unknown	0 – 750	Conductor	Overhead
224	PG&E	07/20/17	01:46	36.52545	-119.68200	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100830639	Unknown	0 – 750	Lightning Arrestor	Overhead
225	PG&E	07/20/17	04:27	38.06420	-120.87106	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	chris costales 209 754 2735	102142834	Unknown	12,000	Conductor	Overhead
226	PG&E	07/20/17	13:45	35.08036	-120.55383	Vegetation	Rural	10 - 99 Acres	Fire Agency	PAUL LEE 805 903-3416 INC # 8291	101941116	Unknown	12,000	Conductor	Overhead
227	PG&E	07/20/17	17:00	37.92651	-121.23203	Vegetation	Urban	< 3 Meters	Customer	N.A.	103384380	PACIFIC BELL	12,000	Capacitor Bank	Overhead
228	PG&E	07/21/17	13:27	38.26854	-120.93718	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	101245524	Unknown	12,000	Conductor	Overhead
229	PG&E	07/21/17	20:26	41.06550	-121.39320	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101549629	Unknown	12,000	Conductor	Overhead
230	PG&E	07/22/17	12:25	40.87950	-123.76380	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Josh , comander chief of forest service.	100980577	Unknown	12,000	Conductor	Overhead
231	PG&E	07/22/17	14:38	37.29945	-122.16306	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100265488	Unknown	12,000	Conductor	Overhead
232	PG&E	07/22/17	16:01	40.83143	-124.05389	Vegetation	Rural	< 0.25 Acres	Fire Agency	BATTALION CHIEF CURT WATKINS, 707-825.2000	100983827	PACIFIC BELL	12,000	Conductor	Overhead
233	PG&E	07/23/17	09:22	40.64201	-122.23025	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT?	101459708	FRONTIER COMM	12,000	Conductor	Overhead
234	PG&E	07/23/17	16:32	36.24055	-119.81283	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	100783832	Unknown	12,000	Conductor	Overhead
235	PG&E	07/23/17	18:25	39.67233	-123.53360	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103823226	Unknown	12,000	Conductor	Overhead
236	PG&E	07/23/17	19:41	36.21714	-119.90973	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	103846605	Unknown	12,000	Conductor	Overhead
237	PG&E	07/24/17	14:01	37.26349	-122.33643	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike klink 650-879-0121	100322130	Unknown	0 – 750	Conductor	Overhead
238	PG&E	07/24/17	16:07	37.25369	-121.96760	Vegetation	Urban	< 0.25 Acres	Fire Agency	C1702050039	103447162	Unknown	0 – 750	Conductor	Overhead
239	PG&E	07/24/17	19:31	38.35192	-120.71029	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101263632	Unknown	12,000	Conductor	Overhead
240	PG&E	07/24/17	21:45	35.60243	-120.92107	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101860186	Unknown	12,000	Conductor	Overhead
241	PG&E	07/25/17	15:51	38.37795	-122.53878	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102031447	Unknown	12,000	Conductor	Overhead
242	PG&E	07/25/17	19:12	39.59970	-121.44490	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100403612	Unknown	12,000	Conductor	Overhead
243	PG&E	07/26/17	06:55	36.78124	-119.75525	Vegetation	Urban	< 3 Meters	Fire Agency	FRESNO FIRE, BATALION 1, FULMER 559 993 2661	100866522	PACIFIC BELL	12,000	Conductor	Overhead
244	PG&E	07/28/17	14:02	40.99973	-121.95793	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101512624	Unknown	12,000	Conductor	Overhead
245	PG&E	07/28/17	16:57	35.47270	-120.99080	Vegetation	Rural	10 - 99 Acres	Fire Agency	TOM MCEWEN 805-903-3409	101933868	Unknown	12,000	Conductor	Overhead
246	PG&E	07/28/17	19:20	35.72756	-120.99030	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	San Luis Obispo CDF	101945496	None	21,000	Conductor	Overhead
247	PG&E	07/29/17	13:18	39.46313	-121.45951	Vegetation	Rural	< 0.25 Acres	Fire Agency	russ fowler 530 521 8056	103846763	Unknown	12,000	Conductor	Overhead
248	PG&E	07/29/17	13:28	35.45229	-120.38344	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101889516	Unknown	0 – 750	Conductor	Overhead
249	PG&E	07/29/17	14:52	37.05999	-122.00113	Vegetation	Urban	< 0.25 Acres	Fire Agency	Scotts Valley Fire Dept.	101679068	PACIFIC BELL	21,000	Conductor	Overhead
250	PG&E	07/29/17	17:56	37.02507	-121.53583	Vegetation	Rural	< 3 Meters	Fire Agency	GEORGE MARSHALL	100610842	Unknown	21,000	Conductor	Overhead
251	PG&E	07/29/17	18:08	37.94875	-121.34571	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	102126507	Unknown	12,000	Conductor	Overhead
252	PG&E	07/29/17	20:45	35.45171	-120.61711	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101941008	Unknown	0 – 750	Conductor	Overhead
253	PG&E	07/30/17	09:46	38.91318	-122.61788	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike wink	102151066	None	0 – 750	Conductor	Overhead
254	PG&E	07/31/17	12:58	37.09707	-122.27965	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101679025	Unknown	0 – 750	Conductor	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
255	PG&E	07/31/17	14:10	35.97865	-120.11100	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	100695130	Unknown	21,000	Conductor	Overhead
256	PG&E	07/31/17	14:41	38.79675	-121.13288	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103782414	Unknown	12,000	Conductor	Overhead
257	PG&E	08/01/17	12:23	36.04123	-119.50529	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100661556	Unknown	0 – 750	Other	Overhead
258	PG&E	08/02/17	9:42	39.22744	-123.10811	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Pole 5/0	None	60,000	Conductor	Overhead
259	PG&E	08/02/17	5:54	40.79856	-123.39614	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100974913	Unknown	12,000	Conductor	Overhead
260	PG&E	08/02/17	8:58	37.56179	-121.94860	Vegetation	Rural	< 0.25 Acres	Fire Agency	FREMONT FIRE DEPT. 911	100940374	PACIFIC BELL	12,000	Other	Overhead
261	PG&E	08/02/17	17:04	37.31632	-122.07225	Vegetation	Urban	< 0.25 Acres	Fire Agency	TONY RAINIERI 408-378-4010	100534186	Unknown	12,000	Conductor	Overhead
262	PG&E	08/02/17	18:16	37.39296	-120.62127	Vegetation	Urban	< 3 Meters	Fire Agency	2099663621	101190510	PACIFIC BELL	12,000	Transformer	Overhead
263	PG&E	08/03/17	10:53	39.07320	-121.08679	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100072742	PACIFIC BELL	12,000	Conductor	Overhead
264	PG&E	08/03/17	11:16	38.11924	-122.50154	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SSR172150008	102227219	Unknown	12,000	Conductor	Overhead
265	PG&E	08/03/17	22:44	39.07110	-121.48700	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	ART PAQUETTE 530-633-0861	101335644	PACIFIC BELL	12,000	Unknown	Overhead
266	PG&E	08/04/17	09:54	38.60394	-121.05918	Vegetation	Rural	< 3 Meters	Fire Agency	D. Franks 530-622-3858, Incident #022602	101411052	PACIFIC BELL	21,000	Capacitor Bank	Overhead
267	PG&E	08/04/17	18:14	35.61928	-120.65890	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101912293	PACIFIC BELL	12,000	Fuse	Overhead
268	PG&E	08/05/17	08:33	38.45835	-120.86954	Vegetation	Rural	< 0.25 Acres	Fire Agency	JEFF MICHEL - 530 409 2223	101236223	Unknown	0 – 750	Conductor	Overhead
269	PG&E	08/05/17	18:08	39.09683	-123.21466	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	102196629	Unknown	12,000	Conductor	Overhead
270	PG&E	08/05/17	18:09	36.96750	-120.08993	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	911	101136476	Unknown	12,000	Conductor	Overhead
271	PG&E	08/05/17	19:21	36.76912	-119.61010	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100725102	Unknown	12,000	Other	Overhead
272	PG&E	08/06/17	11:38	36.58574	-121.71213	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101747125	Unknown	12,000	Conductor	Overhead
273	PG&E	08/06/17	18:21	40.60120	-122.23460	Vegetation	Rural	< 3 Meters	Fire Agency	17CASH4007992	101470083	Unknown	12,000	Other	Overhead
274	PG&E	08/08/17	13:46	38.43664	-122.72596	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	Tower 005/090	None	115,000	Conductor	Overhead
275	PG&E	08/08/17	0:36	35.42687	-119.05719	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100167715	PACIFIC BELL	12,000	Unknown	Subsurface
276	PG&E	08/08/17	4:10	38.49485	-122.66849	Vegetation	Rural	< 3 Meters	Fire Agency	911	102025742	PACIFIC BELL	12,000	Transformer	Overhead
277	PG&E	08/08/17	11:27	37.04448	-121.63431	Vegetation	Urban	< 3 Meters	Utility: PG&E	N.A.	100613200	VERIZON CALIFO	21,000	Capacitor Bank	Overhead
278	PG&E	08/08/17	20:35	37.26367	-119.71027	Vegetation	Rural	< 0.25 Acres	Fire Agency	TROY CHEEK1-209-966-3621	103793352	Unknown	0 – 750	Conductor	Overhead
279	PG&E	08/09/17	11:29	38.65323	-120.62732	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101402496	PACIFIC BELL	21,000	Conductor	Overhead
280	PG&E	08/11/17	07:55	38.26485	-120.97476	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101253880	None	12,000	Conductor	Overhead
281	PG&E	08/12/17	09:08	34.66890	-120.02860	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103391912	Unknown	12,000	Conductor	Overhead
282	PG&E	08/13/17	13:11	38.50939	-122.77004	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	101961046	PACIFIC BELL	12,000	Conductor	Overhead
283	PG&E	08/14/17	6:14	40.11642	-123.80645	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100986364	Unknown	12,000	Conductor	Overhead
284	PG&E	08/14/17	23:52	37.12721	-122.16895	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Pole 015/127	None	60,000	Conductor	Overhead
285	PG&E	08/14/17	07:56	39.17938	-120.97608	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100083743	PACIFIC BELL	12,000	Conductor	Overhead
286	PG&E	08/15/17	19:28	39.50371	-121.27826	Vegetation	Rural	< 3 Meters	Unknown	N.A.	100396172	PACIFIC BELL	12,000	Conductor	Overhead
287	PG&E	08/16/17	20:24	35.78134	-119.91533	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Span 0/6 to 0/7	None	70,000	Conductor	Overhead
288	PG&E	08/17/17	2:33	39.19342	-121.42271	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	101304315	Unknown	12,000	Conductor	Overhead
289	PG&E	08/17/17	15:15	39.37033	-121.04842	Vegetation	Rural	< 0.25 Acres	Fire Agency	PHIL MICHAEL 265-2894 INCIENT # CA NEV 21642	100083029	PACIFIC BELL	12,000	Conductor	Overhead
290	PG&E	08/18/17	17:09	37.09214	-121.66909	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100608897	VERIZON CALIFO	21,000	Conductor	Overhead
291	PG&E	08/19/17	11:31	37.68910	-121.25060	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102053834	Unknown	17,000	Conductor	Overhead
292	PG&E	08/19/17	21:16	40.57523	-122.29847	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101464623	PACIFIC BELL	12,000	Conductor	Overhead
293	PG&E	08/20/17	11:38	39.27636	-122.14067	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101634861	Unknown	12,000	Conductor	Overhead
294	PG&E	08/21/17	15:07	38.60798	-122.35312	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Aaron Latta 707 339 2918	102254922	PACIFIC BELL	0 – 750	Conductor	Overhead
295	PG&E	08/21/17	19:31	39.72577	-121.82052	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100341323	PACIFIC BELL	12,000	Conductor	Overhead
296	PG&E	08/22/17	14:17	38.49020	-122.89178	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102001687	Unknown	0 – 750	Conductor	Overhead
297	PG&E	08/24/17	6:32	36.59050	-119.59286	Vegetation	Rural	< 3 Meters	Fire Agency	ca fku 012333	100897456	Unknown	12,000	Conductor	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
298	PG&E	08/25/17	9:47	39.02509	-121.57752	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101314075	Unknown	21,000	Conductor	Overhead
299	PG&E	08/26/17	7:10	38.82516	-121.39528	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100101888	Unknown	0 – 750	Conductor	Overhead
300	PG&E	08/26/17	20:39	38.47073	-122.64717	Vegetation	Urban	< 3 Meters	Fire Agency	Santa Rosa Fire Dept	101966474	PACIFIC BELL	12,000	Conductor	Overhead
301	PG&E	08/26/17	20:53	38.70657	-121.01929	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101382231	Unknown	0 – 750	Conductor	Overhead
302	PG&E	08/27/17	18:11	37.99158	-121.34788	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Unknown	103193823	Unknown	21,000	Conductor	Overhead
303	PG&E	08/27/17	20:04	38.91654	-121.15100	Vegetation	Rural	< 0.25 Acres	Fire Agency	530-477-0641 x7, log 22629	100077184	PACIFIC BELL	12,000	Conductor	Overhead
304	PG&E	08/27/17	22:16	37.35848	-120.85030	Vegetation	Rural	< 0.25 Acres	Fire Agency	CHRIS ALLEN 209-634-7086	103346364	Unknown	12,000	Conductor	Overhead
305	PG&E	08/28/17	6:32	35.42183	-119.03040	Vegetation	Urban	< 0.25 Acres	Fire Agency	BCFD/KCFD 661-324-6551	103139674	Unknown	0 – 750	Conductor	Overhead
306	PG&E	08/28/17	8:36	35.72450	-119.53414	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	100171751	Unknown	12,000	Conductor	Overhead
307	PG&E	08/28/17	9:14	38.74430	-122.64906	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	103781085	Unknown	0 – 750	Conductor	Overhead
308	PG&E	08/28/17	10:07	39.04720	-120.78589	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	FORESTHILL	100019525	Unknown	12,000	Conductor	Overhead
309	PG&E	08/28/17	13:55	37.68570	-120.80670	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	102327313	None	0 – 750	Conductor	Overhead
310	PG&E	08/28/17	14:06	38.63402	-122.41945	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	102253236	Unknown	21,000	Conductor	Overhead
311	PG&E	08/28/17	14:23	38.50540	-120.75916	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101260228	PACIFIC BELL	12,000	Fuse	Overhead
312	PG&E	08/28/17	14:59	40.28528	-123.87278	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100990599	Unknown	12,000	Conductor	Overhead
313	PG&E	08/28/17	23:56	40.11971	-123.64400	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103844288	Unknown	12,000	Conductor	Overhead
314	PG&E	08/29/17	6:08	38.23650	-122.46080	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101998998	Unknown	12,000	Conductor	Overhead
315	PG&E	08/29/17	10:27	38.36871	-122.00121	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	101661402	PACIFIC BELL	12,000	Lightning Arrestor	Overhead
316	PG&E	08/29/17	10:40	38.20657	-121.15763	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102082031	Unknown	12,000	Conductor	Overhead
317	PG&E	08/29/17	12:49	37.45070	-119.64538	Vegetation	Rural	> 5000 Acres	Fire Agency	USFS	101017368	Unknown	12,000	Conductor	Overhead
318	PG&E	08/29/17	15:54	38.30196	-122.54314	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	911	102026119	PACIFIC BELL	12,000	Fuse	Overhead
319	PG&E	08/30/17	16:17	35.35283	-119.05377	Vegetation	Urban	< 0.25 Acres	Fire Agency	BCFD/KCFD 661-324-6551	100145928	Unknown	0 – 750	Conductor	Overhead
320	PG&E	08/30/17	18:21	40.62430	-122.30386	Vegetation	Rural	< 0.25 Acres	Fire Agency	CASHU008896	103151338	YES	12,000	Conductor	Overhead
321	PG&E	08/30/17	22:37	38.99933	-120.98871	Vegetation	Rural	< 3 Meters	Fire Agency	Andy 530-889-0111	100026238	PACIFIC BELL	12,000	Conductor	Overhead
322	PG&E	08/30/17	22:39	38.16621	-121.93815	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	suisun	103850994	Unknown	12,000	Conductor	Overhead
323	PG&E	08/31/17	6:42	35.61599	-120.85770	Vegetation	Rural	< 0.25 Acres	Fire Agency	Derrick	101860075	Unknown	21,000	Conductor	Overhead
324	PG&E	08/31/17	11:33	37.13786	-121.99658	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100519201	Unknown	21,000	Conductor	Overhead
325	PG&E	08/31/17	11:51	38.39169	-122.31951	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102291943	PACIFIC BELL	21,000	Conductor	Overhead
326	PG&E	08/31/17	21:07	41.06048	-124.10377	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100977438	Unknown	12,000	Conductor	Overhead
327	PG&E	08/31/17	22:50	36.81501	-119.77632	Vegetation	Urban	< 3 Meters	Customer	N.A.	100851402	PACIFIC BELL	0 – 750	Conductor	Overhead
328	PG&E	09/01/17	6:09	36.19489	-120.70786	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101705717	Unknown	12,000	Fuse	Overhead
329	PG&E	09/01/17	8:00	37.37567	-119.88862	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101067028	Unknown	0 – 750	Conductor	Overhead
330	PG&E	09/01/17	12:07	40.59381	-124.13596	Vegetation	Rural	< 3 Meters	Fire Agency	DISPATCH FIRE 707-725-7550	100993250	PACIFIC BELL	12,000	Lightning Arrestor	Overhead
331	PG&E	09/01/17	12:52	37.16670	-121.70690	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100601982	VERIZON CALIFO	21,000	Conductor	Overhead
332	PG&E	09/01/17	12:59	38.45270	-122.78450	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102015626	PACIFIC BELL	12,000	Fuse	Overhead
333	PG&E	09/01/17	17:48	36.65180	-121.72490	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	MCFD	103155761	Unknown	12,000	Conductor	Overhead
334	PG&E	09/01/17	18:42	38.29390	-122.50390	Other	Rural	< 0.25 Acres	Fire Agency	BOB NORRBOM 707 996 2102	101982894	PACIFIC BELL	12,000	Fuse	Overhead
335	PG&E	09/02/17	12:01	37.66445	-121.92227	Vegetation	Rural	< 3 Meters	Customer	N.A.	100956020	PACIFIC BELL	21,000	Conductor	Overhead
336	PG&E	09/02/17	16:18	37.26897	-121.80564	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100584311	PACIFIC BELL	0 – 750	Conductor	Overhead
337	PG&E	09/02/17	18:00	37.93380	-122.40690	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102347407	PACIFIC BELL	12,000	Conductor	Overhead
338	PG&E	09/03/17	7:12	37.37432	-122.21838	Vegetation	Rural	< 0.25 Acres	Fire Agency	Local	100270106	Unknown	12,000	Conductor	Overhead
339	PG&E	09/03/17	12:52	37.21616	-119.48067	Vegetation	Rural	1000 - 4999 Acres	Fire Agency	Cal Fire	103345573	Unknown	0 – 750	Conductor	Overhead
340	PG&E	09/03/17	17:52	37.49559	-119.83667	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	209-966-3621	101086621	Unknown	21,000	Transformer	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
341	PG&E	09/03/17	22:57	36.09533	-120.51699	Vegetation	Rural	100 - 299 Acres	Fire Agency	CHRIS CHRISTOPHERSON 559-281-4320	100739435	PACIFIC BELL	12,000	Conductor	Overhead
342	PG&E	09/04/17	0:57	36.80240	-119.82540	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100856132	PACIFIC BELL	0 – 750	Conductor	Overhead
343	PG&E	09/04/17	3:29	39.83171	-121.84441	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	102300100	PACIFIC BELL	12,000	Conductor	Overhead
344	PG&E	09/04/17	6:43	37.45463	-121.93311	Other	Rural	Structure Only	Customer	N.A.	100557780	PACIFIC BELL	21,000	Conductor	Overhead
345	PG&E	09/05/17	1:24	39.43168	-121.55285	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100420238	PACIFIC BELL	12,000	Conductor	Overhead
346	PG&E	09/05/17	6:58	39.67273	-123.51279	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	102194697	VERIZON CALIFO	12,000	Conductor	Overhead
347	PG&E	09/05/17	7:20	39.71095	-121.79724	Vegetation	Rural	< 3 Meters	Fire Agency	(530) 538-6841	100355255	Unknown	12,000	Conductor	Overhead
348	PG&E	09/05/17	13:51	38.18972	-121.31746	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103218208	Unknown	12,000	Conductor	Overhead
349	PG&E	09/05/17	17:51	38.34067	-122.25777	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102284869	PACIFIC BELL	12,000	Conductor	Overhead
350	PG&E	09/06/17	19:26	40.83920	-122.36350	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103643183	Unknown	12,000	Conductor	Overhead
351	PG&E	09/06/17	20:08	37.29255	-122.29403	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100256917	Unknown	12,000	Conductor	Overhead
352	PG&E	09/08/17	4:47	38.74778	-120.85905	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101391575	PACIFIC BELL	12,000	Conductor	Overhead
353	PG&E	09/08/17	17:21	38.60388	-120.92748	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101379094	PACIFIC BELL	21,000	Conductor	Overhead
354	PG&E	09/08/17	21:14	37.96038	-120.37636	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	John Lite 209-984-5623	101042521	Unknown	17,000	Conductor	Overhead
355	PG&E	09/09/17	18:36	36.66181	-121.54766	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101769870	Unknown	12,000	Conductor	Overhead
356	PG&E	09/10/17	1:22	39.25988	-121.49023	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	TYLER LOPEZ	101289867	None	12,000	Conductor	Overhead
357	PG&E	09/10/17	16:30	37.30393	-120.52747	Vegetation	Rural	10 - 99 Acres	Fire Agency	Merced County FD	101161316	PACIFIC BELL	0 – 750	Conductor	Overhead
358	PG&E	09/11/17	7:18	37.00083	-121.66674	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100621936	VERIZON CALIFO	0 – 750	Conductor	Overhead
359	PG&E	09/11/17	8:50	36.95146	-121.84204	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101790954	PACIFIC BELL	21,000	Fuse	Overhead
360	PG&E	09/11/17	23:50	40.86724	-124.08827	Vegetation	Urban	< 3 Meters	Fire Agency	BOB	100964579	Unknown	12,000	Conductor	Overhead
361	PG&E	09/12/17	9:24	39.74095	-121.60787	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	100330302	PACIFIC BELL	12,000	Conductor	Overhead
362	PG&E	09/12/17	17:18	39.45106	-121.60519	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	tom klage 530 538-7888	100419482	Unknown	12,000	Conductor	Overhead
363	PG&E	09/14/17	11:02	39.11112	-121.55647	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101320308	None	12,000	Switch	Overhead
364	PG&E	09/14/17	12:09	39.50393	-121.54528	Vegetation	Urban	< 0.25 Acres	Fire Agency	530-538-2448	100372805	Unknown	12,000	Conductor	Overhead
365	PG&E	09/14/17	14:06	40.29421	-123.81736	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100989497	Unknown	12,000	Conductor	Overhead
366	PG&E	09/15/17	14:55	39.74607	-121.48853	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100335239	Unknown	12,000	Conductor	Overhead
367	PG&E	09/17/17	15:05	36.64729	-119.38613	Vegetation	Rural	< 3 Meters	Customer	N.A.	100738741	VERIZON CALIFO	0 – 750	Conductor	Overhead
368	PG&E	09/17/17	17:38	38.99459	-121.02607	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100029537	PACIFIC BELL	12,000	Conductor	Overhead
369	PG&E	09/18/17	13:01	39.38885	-121.40538	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	103795057	Unknown	0 – 750	Conductor	Overhead
370	PG&E	09/18/17	15:10	39.60135	-122.05551	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103849874	Unknown	12,000	Conductor	Overhead
371	PG&E	09/18/17	18:01	38.21975	-122.54300	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101997149	Unknown	12,000	Conductor	Overhead
372	PG&E	09/18/17	19:01	38.07423	-122.82861	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102229215	PACIFIC BELL	12,000	Conductor	Overhead
373	PG&E	09/18/17	23:50	37.90879	-120.48652	Vegetation	Rural	10 - 99 Acres	Fire Agency	incident comander geoff marshall 209-419-4407	101040882	Unknown	17,000	Conductor	Overhead
374	PG&E	09/19/17	19:13	35.47836	-119.29591	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100207112	Unknown	12,000	Conductor	Overhead
375	PG&E	09/20/17	2:06	37.25968	-122.32223	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100322388	PACIFIC BELL	12,000	Conductor	Overhead
376	PG&E	09/20/17	8:41	36.94037	-120.90142	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 2/6 - Arburua Tap	None	70,000	Conductor	Overhead
377	PG&E	09/21/17	8:39	39.61470	-121.72582	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	100347380	Unknown	0 – 750	Conductor	Overhead
378	PG&E	09/22/17	14:28	36.09612	-120.05766	Vegetation	Rural	< 0.25 Acres	Fire Agency	SAME AS TAG. FD NOT STANDING BY UPON ARRIVAL	100663084	Unknown	12,000	Capacitor Bank	Overhead
379	PG&E	09/23/17	9:16	37.01267	-120.62562	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101181497	Unknown	12,000	Conductor	Overhead
380	PG&E	09/23/17	14:17	40.65090	-122.29740	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	DARREN STEWART 448- 2421	101467221	PACIFIC BELL	12,000	Conductor	Overhead
381	PG&E	09/24/17	2:13	38.10460	-120.98901	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 016/297	Unknown	60,000	Conductor	Overhead
382	PG&E	09/24/17	7:54	37.40140	-122.02740	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100515206	PACIFIC BELL	12,000	Conductor	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
383	PG&E	09/24/17	16:42	38.38690	-122.96670	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	DOUG JONES	101973946	PACIFIC BELL	12,000	Conductor	Overhead
384	PG&E	09/25/17	19:49	36.81370	-121.72098	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Tower 058/249	Unknown	230,000	Conductor	Overhead
385	PG&E	09/26/17	17:44	38.06427	-122.80563	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102228291	Unknown	12,000	Other	Overhead
386	PG&E	09/27/17	9:11	39.01626	-122.86854	Vegetation	Rural	< 3 Meters	Customer	N.A.	102143577	PACIFIC BELL	12,000	Transformer	Overhead
387	PG&E	09/27/17	12:12	39.48450	-121.35450	Vegetation	Rural	< 0.25 Acres	Fire Agency	bill lopez cell 530 521-8052	100429924	PACIFIC BELL	12,000	Fuse	Overhead
388	PG&E	09/27/17	19:06	40.75920	-123.99500	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103660812	Unknown	12,000	Conductor	Overhead
389	PG&E	09/28/17	18:28	37.98840	-122.09700	Vegetation	Urban	< 3 Meters	Fire Agency	(510)374-7070	103627505	Unknown	21,000	Conductor	Overhead
390	PG&E	09/29/17	2:01	39.53174	-122.18567	Vegetation	Urban	< 3 Meters	Unknown	N.A.	100419384	Unknown	21,000	Transformer	Padmounted
391	PG&E	09/30/17	15:08	37.41091	-121.17474	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Tower 030/132	None	230,000	Conductor	Overhead
392	PG&E	10/01/17	7:24	37.91400	-122.37710	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101437028	Unknown	12,000	Transformer	Overhead
393	PG&E	10/01/17	16:11	39.79696	-122.11853	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103850270	Unknown	0 - 750	Conductor	Overhead
394	PG&E	10/01/17	23:51	40.01920	-122.14520	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	MARK FRITZ	101534592	Unknown	12,000	Conductor	Overhead
395	PG&E	10/02/17	2:55	37.33137	-120.52428	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	209-966-3621	101160137	Unknown	12,000	Conductor	Overhead
396	PG&E	10/02/17	7:07	38.29490	-122.10660	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101658181	Unknown	0 - 750	Transformer	Overhead
397	PG&E	10/02/17	12:22	39.63135	-122.00685	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	103224422	Unknown	12,000	Conductor	Overhead
398	PG&E	10/02/17	14:56	38.91023	-120.91853	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100110800	None	21,000	Other	Overhead
399	PG&E	10/02/17	16:05	38.71820	-120.97560	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101375963	Unknown	21,000	Conductor	Overhead
400	PG&E	10/02/17	17:30	38.36340	-122.28458	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	102282538	PACIFIC BELL	12,000	Conductor	Overhead
401	PG&E	10/03/17	17:48	35.10842	-119.37855	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	span 001/019 - 001/020	Unknown	70,000	Conductor	Overhead
402	PG&E	10/04/17	12:20	37.81692	-121.27147	Vegetation	Rural	< 0.25 Acres	Fire Agency	LATHROP	102091094	Unknown	0 - 750	Other	Overhead
403	PG&E	10/04/17	23:42	38.65539	-120.99340	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101375442	PACIFIC BELL	12,000	Other	Overhead
404	PG&E	10/05/17	0:20	38.00524	-121.75446	Vegetation	Rural	< 3 Meters	Fire Agency	911	100456226	Unknown	21,000	Switch	Subsurface
405	PG&E	10/05/17	10:57	39.46636	-122.16704	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100343435	PACIFIC BELL	21,000	Other	Overhead
406	PG&E	10/06/17	7:24	38.56070	-121.76425	Vegetation	Urban	< 3 Meters	Fire Agency	5307583600	101639481	PACIFIC BELL	12,000	Lightning Arrestor	Overhead
407	PG&E	10/06/17	12:03	39.46450	-122.11238	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100344016	Unknown	21,000	Conductor	Overhead
408	PG&E	10/06/17	16:04	40.97124	-124.03716	Vegetation	Rural	< 0.25 Acres	Fire Agency	JO BOB	100978977	Unknown	12,000	Conductor	Overhead
409	PG&E	10/07/17	10:11	37.19880	-121.83250	Vegetation	Urban	< 0.25 Acres	Fire Agency	JOHN PAVLOFF	100600703	PACIFIC BELL	21,000	Other	Overhead
410	PG&E	10/08/17	5:11	40.32520	-124.28810	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100987374	FRONTIER COMM	12,000	Conductor	Overhead
411	PG&E	10/08/17	16:41	39.58900	-122.20150	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100341037	Unknown	0 - 750	Conductor	Overhead
412	PG&E	10/08/17	16:43	40.88760	-123.99175	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100972408	Unknown	12,000	Conductor	Overhead
413	PG&E	10/08/17	17:39	38.53311	-121.54236	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101585529	Unknown	12,000	Conductor	Overhead
414	PG&E	10/08/17	19:11	37.20714	-121.86200	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100622560	PACIFIC BELL	0 - 750	Conductor	Overhead
415	PG&E	10/08/17	19:44	39.74459	-121.59704	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	100330456	Unknown	12,000	Conductor	Overhead
416	PG&E	10/08/17	20:35	39.63150	-121.42250	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100347747	Unknown	12,000	Conductor	Overhead
417	PG&E	10/08/17	21:10	39.45540	-121.04981	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100099226	Unknown	12,000	Conductor	Overhead
418	PG&E	10/08/17	21:46	39.25949	-120.99650	Vegetation	Urban	< 0.25 Acres	Fire Agency	PHILLIP NUNNICK 530 273-3158 INCENDENT # 26264	100072730	PACIFIC BELL	12,000	Other	Overhead
419	PG&E	10/08/17	22:19	39.73711	-121.64642	Vegetation	Rural	< 3 Meters	Fire Agency	911	103319605	Unknown	0 - 750	Conductor	Overhead
420	PG&E	10/08/17	22:30	38.32262	-121.94307	Vegetation	Rural	< 0.25 Acres	Fire Agency	vaca	101561309	PACIFIC BELL	21,000	Conductor	Overhead
421	PG&E	10/08/17	22:54	35.55276	-118.96809	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	pan 7/87-7/88, Vedder Ta	Unknown	115,000	Conductor	Overhead
422	PG&E	10/08/17	22:58	39.36423	-121.11307	Vegetation	Rural	< 3 Meters	Fire Agency	INCIDENT NUMBER 26268	100068104	PACIFIC BELL	12,000	Conductor	Overhead
423	PG&E	10/08/17	23:51	38.27585	-121.96167	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	707-428-7305	101660727	PACIFIC BELL	0 - 750	Conductor	Overhead
424	PG&E	10/09/17	1:02	38.70368	-120.67250	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101408485	Unknown	21,000	Other	Overhead
425	PG&E	10/09/17	1:13	38.10103	-122.21965	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102218775	PACIFIC BELL	0 - 750	Conductor	Overhead
426	PG&E	10/09/17	1:25	38.19062	-121.94974	Vegetation	Rural	10 - 99 Acres	Unknown	N.A.	101559973	Unknown	21,000	Conductor	Overhead
427	PG&E	10/09/17	1:29	37.84157	-121.95827	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100501933	PACIFIC BELL	0 - 750	Conductor	Overhead
428	PG&E	10/09/17	1:45	38.85755	-122.72207	Vegetation	Rural	< 0.25 Acres	Fire Agency	wink	103570679	Unknown	12,000	Conductor	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
429	PG&E	10/09/17	2:27	37.72931	-122.13783	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100903727	PACIFIC BELL	12,000	Conductor	Overhead
430	PG&E	10/09/17	4:36	38.26428	-122.04877	Vegetation	Urban	< 3 Meters	Fire Agency	Fairfield	101660707	Unknown	0 – 750	Conductor	Overhead
431	PG&E	10/09/17	12:05	35.40672	-118.96231	Vegetation	Urban	< 3 Meters	Customer	N.A.	100252698	PACIFIC BELL	0 – 750	Conductor	Overhead
432	PG&E	10/10/17	13:36	38.93098	-123.30235	Vegetation	Rural	< 3 Meters	Customer	N.A.	102214553	Unknown	0 – 750	Conductor	Overhead
433	PG&E	10/10/17	16:17	38.31478	-122.70673	Vegetation	Urban	.26 - 9.99 Acres	Unknown	N.A.	101996286	PACIFIC BELL	0 – 750	Conductor	Overhead
434	PG&E	10/10/17	16:29	37.25591	-121.95862	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100542800	VERIZON CALIFO	12,000	Conductor	Overhead
435	PG&E	10/11/17	11:57	38.50153	-123.02367	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101974930	Unknown	12,000	Conductor	Overhead
436	PG&E	10/11/17	16:41	38.67900	-121.94870	Vegetation	Rural	< 3 Meters	Fire Agency	ESPARTO FIRE PROTECTION DISTRICT-(530) 787-3300	101591668	Unknown	0 – 750	Conductor	Overhead
437	PG&E	10/13/17	8:30	38.02343	-122.53764	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102246021	Unknown	0 – 750	Transformer	Overhead
438	PG&E	10/13/17	10:27	37.05607	-122.02057	Vegetation	Urban	< 0.25 Acres	Fire Agency	Scotts Valley Fire Dept.	101677721	Unknown	21,000	Conductor	Overhead
439	PG&E	10/13/17	19:15	36.94153	-120.03973	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101224900	PACIFIC BELL	12,000	Conductor	Overhead
440	PG&E	10/13/17	22:19	39.76485	-121.63075	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100325368	PACIFIC BELL	0 – 750	Transformer	Overhead
441	PG&E	10/14/17	8:37	37.39437	-122.09155	Building	Urban	Structure Only	Fire Agency	Unknown	100513237	PACIFIC BELL	12,000	Transformer	Overhead
442	PG&E	10/14/17	14:43	40.11215	-122.17368	Vegetation	Rural	< 0.25 Acres	Self Extinguished	N.A.	101539953	None	12,000	Fuse	Overhead
443	PG&E	10/15/17	13:15	37.38553	-121.81327	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	SA JOSE FD	100563705	Unknown	12,000	Conductor	Overhead
444	PG&E	10/16/17	12:10	36.58307	-121.93676	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101781248	PACIFIC BELL	12,000	Conductor	Overhead
445	PG&E	10/16/17	12:20	37.71998	-122.06870	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100900970	PACIFIC BELL	0 – 750	Conductor	Overhead
446	PG&E	10/16/17	12:26	36.66410	-121.09947	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Nick Shawkey E4462 209-402-1645 Cover Engine from Tuolumne Calaveras Unit	101689865	PACIFIC BELL	0 – 750	Conductor	Overhead
447	PG&E	10/17/17	18:22	35.42566	-119.02972	Vegetation	Urban	< 3 Meters	Self Extinguished	N.A.	100144662	PACIFIC BELL	12,000	Capacitor Bank	Overhead
448	PG&E	10/18/17	13:58	37.63605	-122.07925	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100952408	PACIFIC BELL	0 – 750	Conductor	Overhead
449	PG&E	10/20/17	5:59	36.74749	-119.76295	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100859697	Unknown	12,000	Conductor	Overhead
450	PG&E	10/20/17	6:18	39.29221	-121.01573	Vegetation	Rural	< 3 Meters	Fire Agency	PHILLIP NUNNINK INCIDENT # 27272	100087647	PACIFIC BELL	12,000	Conductor	Overhead
451	PG&E	10/20/17	9:06	36.03599	-120.05797	Vegetation	Rural	300 - 999 Acres	Fire Agency	Unknown	Pole 009/009	Unknown	70,000	Conductor	Overhead
452	PG&E	10/20/17	13:43	35.35300	-119.98730	Vegetation	Rural	10 - 99 Acres	Fire Agency	Kevin McLean Office(805)593-3421, Cell(805)903-3421	100136483	Unknown	12,000	Conductor	Overhead
453	PG&E	10/20/17	13:45	34.55317	-120.53029	Vegetation	Rural	100 - 299 Acres	Fire Agency	Unknown	101921492	Unknown	12,000	Conductor	Overhead
454	PG&E	10/20/17	14:00	36.92155	-119.72828	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100727124	Unknown	21,000	Fuse	Overhead
455	PG&E	10/21/17	15:08	39.06400	-122.77645	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102155186	PACIFIC BELL	12,000	Conductor	Overhead
456	PG&E	10/21/17	16:05	37.59108	-122.00995	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Unknown	103516949	Unknown	0 – 750	Conductor	Overhead
457	PG&E	10/23/17	19:34	36.07720	-121.01900	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101763398	Unknown	12,000	Conductor	Overhead
458	PG&E	10/23/17	21:24	37.37133	-122.34799	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100270421	Unknown	12,000	Conductor	Overhead
459	PG&E	10/24/17	15:23	36.85988	-121.79474	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101789001	PACIFIC BELL	21,000	Conductor	Overhead
460	PG&E	10/26/17	10:53	36.40356	-121.91219	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101777002	Unknown	12,000	Conductor	Overhead
461	PG&E	10/28/17	15:26	39.45162	-123.38381	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102209084	Unknown	12,000	Conductor	Overhead
462	PG&E	10/28/17	20:08	35.02222	-118.76915	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100223850	Unknown	12,000	Fuse	Overhead
463	PG&E	10/31/17	18:56	39.00345	-121.69065	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Pole 010/208	Unknown	60,000	Conductor	Overhead
464	PG&E	10/31/17	21:02	39.11189	-122.91633	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Structure 020/003	Unknown	60,000	Conductor	Overhead
465	PG&E	11/06/17	9:59	37.14600	-121.66753	Vegetation	Rural	< 0.25 Acres	Fire Agency	INCIDENT # 1717CASCU008183	103570543	YES	21,000	Conductor	Overhead
466	PG&E	11/06/17	15:06	38.29980	-122.50300	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101982913	PACIFIC BELL	12,000	Conductor	Overhead
467	PG&E	11/08/17	07:11	37.73669	-120.34587	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101191714	PACIFIC BELL	12,000	Conductor	Overhead
468	PG&E	11/08/17	14:53	37.79198	-122.22211	Building	Urban	Structure Only	Fire Agency	Unknown	101352529	Unknown	4,000	Conductor	Overhead

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Utility Name	Fire Start		Location				Fire			Utility Facility				
2		Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type
469	PG&E	11/11/17	11:57	35.11908	-120.39364	Vegetation	Rural	< 0.25 Acres	Fire Agency	Jordan Dayley ph#929-3911,engine#3467	101931190	PACIFIC BELL	12,000	Conductor	Overhead
470	PG&E	11/12/17	19:44	36.73779	-119.77691	Building	Urban	< 0.25 Acres	Fire Agency	capt will johnson	100871063	Unknown	12,000	Capacitor Bank	Overhead
471	PG&E	11/14/17	07:43	37.32400	-120.81456	Vegetation	Rural	< 3 Meters	Fire Agency	cammu #023223	103853299	Unknown	12,000	Transformer	Overhead
472	PG&E	11/17/17	09:53	37.08016	-120.01945	Other	Rural	< 3 Meters	Utility: PG&E	N.A.	101029626	Unknown	12,000	Fuse	Overhead
473	PG&E	11/20/17	08:32	38.75835	-120.84385	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101389405	PACIFIC BELL	12,000	Conductor	Overhead
474	PG&E	11/20/17	20:05	35.49951	-118.90994	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	661-324-6551	103782809	None	0 – 750	Conductor	Overhead
475	PG&E	11/21/17	11:55	37.61013	-121.33324	Vegetation	Rural	< 0.25 Acres	Fire Agency	tracy fire dept	102053617	PACIFIC BELL	12,000	Conductor	Overhead
476	PG&E	11/22/17	13:44	36.75202	-121.66363	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103154362	Unknown	12,000	Conductor	Overhead
477	PG&E	11/23/17	16:29	35.77554	-120.69413	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101860971	Unknown	12,000	Conductor	Overhead
478	PG&E	11/24/17	10:33	36.62133	-120.06165	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	KERMAN FIRE DEP.	100700090	Unknown	12,000	Conductor	Overhead
479	PG&E	11/25/17	6:29	36.01436	-119.95559	Vegetation	Rural	< 3 Meters	Utility: PG&E	N.A.	100693913	Unknown	12,000	Conductor	Overhead
480	PG&E	11/26/17	10:10	36.70981	-119.56321	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100815464	VERIZON CALIFO	0 – 750	Conductor	Overhead
481	PG&E	11/27/17	06:23	36.69419	-121.65832	Vegetation	Urban	< 3 Meters	Fire Agency	831-758-7261	101723997	Unknown	12,000	Conductor	Overhead
482	PG&E	11/27/17	11:11	37.12962	-122.31244	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100268264	Unknown	12,000	Conductor	Overhead
483	PG&E	11/28/17	15:49	36.49743	-119.79086	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100806272	Unknown	12,000	Other	Overhead
484	PG&E	11/29/17	17:34	38.68410	-120.65461	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	101419450	PACIFIC BELL	21,000	Conductor	Overhead
485	PG&E	12/07/17	12:25	34.71151	-120.17715	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	Pole 015/220	Unknown	115,000	Unknown	Overhead
486	PG&E	12/12/17	4:40	39.77107	-121.59727	Building	Urban	Structure Only	Fire Agency	paradise fire city department	100324902	PACIFIC BELL	12,000	Fuse	Overhead
487	PG&E	12/13/17	12:13	35.59220	-120.64741	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103390807	Unknown	21,000	Other	Overhead
488	PG&E	12/14/17	1:33	37.19789	-121.83746	Building	Rural	Structure Only	Fire Agency	Unknown	100622323	PACIFIC BELL	0 – 750	Conductor	Overhead
489	PG&E	12/14/17	17:16	34.58783	-120.35663	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101911004	VERIZON CALIFO	12,000	Conductor	Overhead
490	PG&E	12/16/17	7:01	39.74474	-122.19612	Building	Urban	Structure Only	Fire Agency	ORLAND CITY FIRE DEPT	100428554	PACIFIC BELL	0 – 750	Conductor	Overhead
491	PG&E	12/16/17	11:51	38.81706	-122.70412	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Shawn Ohare	102167231	PACIFIC BELL	12,000	Conductor	Overhead
492	PG&E	12/16/17	13:39	37.97022	-121.64092	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE CAPTAIN ON DUTY	100473121	PACIFIC BELL	0 – 750	Conductor	Overhead
493	PG&E	12/16/17	16:03	35.65929	-120.49459	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103131190	Unknown	21,000	Conductor	Overhead
494	PG&E	12/19/17	7:05	36.27152	-120.39270	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100745841	Unknown	12,000	Fuse	Overhead
495	PG&E	12/19/17	16:55	35.23093	-119.59840	Vegetation	Rural	< 0.25 Acres	Fire Agency	KC FIRE DEPT	100165540	Unknown	21,000	Conductor	Overhead
496	PG&E	12/19/17	19:45	40.72710	-122.32629	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101457738	Unknown	0 – 750	Conductor	Overhead
497	PG&E	12/20/17	07:54	37.40115	-122.36062	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100318864	PACIFIC BELL	12,000	Conductor	Overhead
498	PG&E	12/20/17	14:03	35.66460	-121.24400	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103857828	Unknown	12,000	Fuse	Overhead
499	PG&E	12/20/17	16:04	34.61055	-120.32180	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101906902	VERIZON CALIFO	12,000	Fuse	Overhead
500	PG&E	12/22/17	14:38	35.33754	-119.06370	Building	Urban	Structure Only	Fire Agency	Unknown	5895SW	Unknown	21,000	Switch	Subsurface
501	PG&E	12/24/17	6:41	37.44444	-122.18976	Building	Urban	Structure Only	Fire Agency	Menlo Park FD	103511827	Unknown	4,000	Conductor	Overhead
502	PG&E	12/24/17	03:53	40.46185	-122.32768	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101496394	Unknown	12,000	Conductor	Overhead
503	PG&E	12/29/17	16:31	37.85168	-122.15863	Vegetation	Rural	< 3 Meters	Fire Agency	925-933-1313	100488954	PACIFIC BELL	12,000	Capacitor Bank	Overhead
504															

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
3	Yes	1/1/17	15:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
4	Yes	1/10/17	15:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
5	Yes	1/18/17	15:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
6	Yes	1/29/17	09:45	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
7	Yes	2/3/17	10:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
8	Yes	2/7/17	04:50	Other	N.A.	N.A.	N.A.	Unknown	
9	Yes	3/16/17	12:43	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
10	Yes	3/17/17	09:37	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
11	Yes	3/19/17	17:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
12	Yes	3/23/17	07:04	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
13	Yes	3/28/17	12:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
14	Yes	4/1/17	14:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
15	Yes	4/4/17	13:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
16	Yes	4/4/17	14:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
17	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
18	Yes	4/13/17	14:21	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
19	Yes	4/16/17	15:14	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
20	No			Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
21	Yes	4/23/17	7:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
22	Yes	4/24/17	11:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	tie wire
23	Yes	4/25/17	12:38	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
24	Yes	4/25/17	18:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
25	Yes	4/26/17	15:55	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
26	Yes	4/28/17	5:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
27	Yes	4/28/17	14:35	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
28	Yes	4/28/17	15:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
29	Yes	4/29/17	15:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
30	Yes	4/30/17	9:32	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
31	Yes	5/1/17	14:20	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
32	Yes	5/3/17	10:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
33	Yes	5/3/17	12:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
34	Yes	5/4/17	16:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
35	Yes	5/5/17	15:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
36	Yes	5/6/17	1:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
37	Yes	5/6/17	11:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
38	Yes	5/6/17	12:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
39	Yes	5/6/17	15:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
40	Yes	5/6/17	23:46	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
41	Yes	5/9/17	11:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
42	No			Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
43	Yes	5/9/17	18:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
44	Yes	5/12/17	15:16	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
45	Yes	5/13/17	21:49	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
46	Yes	5/14/17	11:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
47	Yes	5/14/17	16:09	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
48	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
49	No			Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
50	Yes	5/15/17	16:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
51	Yes	5/15/17	20:57	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
52	Yes	5/16/17	17:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
53	Yes	5/17/17	14:49	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	Transformer fuse
54	Yes	5/17/17	15:13	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
55	Yes	5/19/17	9:37	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	secondary riser
56	Yes	5/19/17	10:52	Contamination	N.A.	N.A.	N.A.	Unknown	
57	Yes	5/20/17	12:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	secondary riser
58	Yes	5/21/17	11:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
59	Yes	5/21/17	22:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
60	No			Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
61	Yes	5/22/17	17:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
62	Yes	5/24/17	16:24	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
63	Yes	5/25/17	11:09	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
64	Yes	5/25/17	15:05	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
65	Yes	5/25/17	16:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
66	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
67	Yes	5/30/17	11:40	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
68	Yes	5/31/17	2:06	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
69	Yes	5/31/17	5:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
70	Yes	6/1/17	9:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
71	Yes	6/1/17	21:35	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
72	Yes	6/1/17	22:14	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
73	Yes	6/3/17	13:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
74	Yes	6/3/17	20:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
75	Yes	6/4/17	00:08	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
76	Yes	6/4/17	13:12	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
77	Yes	6/5/17	0:52	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
78	Yes	6/5/17	7:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
79	Yes	6/5/17	17:12	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
80	Yes	6/6/17	9:15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
81	Yes	6/6/17	09:48	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
82	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
83	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
84	Yes	6/7/17	10:13	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
85	Yes	6/8/17	5:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
86	Yes	6/8/17	0:26	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
87	Yes	6/8/17	15:08	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
88	Yes	6/9/17	10:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
89	Yes	6/9/17	13:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
90	Yes	6/9/17	17:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
91	Yes	6/10/17	07:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
92	Yes	6/12/17	15:28	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
93	Yes	6/12/17	18:04	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
94	Yes	6/13/17	14:30	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
95	Yes	6/14/17	22:23	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
96	Yes	6/15/17	2:58	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	power theft
97	Yes	6/15/17	5:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
98	Yes	6/15/17	7:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
99	Yes	6/15/17	15:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
100	Yes	6/15/17	16:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
101	Yes	6/15/17	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
102	Yes	6/16/17	13:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
103	Yes	6/16/17	14:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
104	Yes	6/16/17	16:17	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
105	Yes	6/16/17	17:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
106	Yes	6/16/17	19:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
107	Yes	6/16/17	22:30	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
108	Yes	6/17/17	02:53	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
109	Yes	6/17/17	15:49	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
110	Yes	6/18/17	23:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
111	Yes	6/18/17	12:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
112	Yes	6/18/17	13:10	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
113	Yes	6/18/17	18:09	Equipment/ Facility Failure	Guy/Span Wire	N.A.	N.A.	Unknown	
114	Yes	6/18/17	20:16	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
115	Yes	6/18/17	21:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
116	Yes	6/18/17	22:12	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
117	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
118	Yes	6/18/17	23:31	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
119	Yes	6/19/17	01:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
120	Yes	6/19/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
121	Yes	6/19/17	16:18	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
122	No			Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
123	Yes	6/19/17	17:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
124	Yes	6/19/17	18:00	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
125	Yes	6/19/17	20:22	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
126	Yes	6/20/17	00:49	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
127	Yes	6/20/17	09:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
128	Yes	6/20/17	10:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
129	Yes	6/20/17	13:37	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
130	Yes	6/20/17	15:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
131	Yes	6/20/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
132	Yes	6/20/17	18:32	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
133	Yes	6/20/17	20:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
134	Yes	6/20/17	23:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
135	Yes	6/21/17	08:41	Contact From Object	N.A.	Other	Electric Facility	Human Error	helicopter
136	Yes	6/21/17	14:23	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
137	Yes	6/22/17	9:36	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
138	Yes	6/22/17	16:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
139	Yes	6/22/17	18:07	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
140	Yes	6/22/17	19:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
141	Yes	6/23/17	13:00	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	power theft
142	Yes	6/23/17	20:09	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster bank
143	Yes	6/23/17	19:23	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
144	Yes	6/24/17	10:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
145	Yes	6/24/17	14:51	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
146	Yes	6/24/17	22:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
147	Yes	6/25/17	0.7625	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
148	Yes	6/25/17	0:23	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
149	Yes	6/25/17	6:02	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
150	Yes	6/25/17	15:37	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
151	Yes	6/25/17	22:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
152	Yes	6/26/17	8:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
153	Yes	6/26/17	14:29	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
154	Yes	6/27/17	9:23	Other	N.A.	N.A.	N.A.	Unknown	
155	Yes	6/27/17	17:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
156	No			Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
157	Yes	6/28/17	13:09	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
158	Yes	6/29/17	18:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
159	Yes	6/29/17	21:55	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
160	Yes	6/30/17	10:24	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
161	Yes	6/30/17	01:20	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
162	Yes	6/30/17	23:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
163	Yes	7/1/17	12:02	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
164	Yes	7/1/17	3:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
165	Yes	7/1/17	3:12	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
166	Yes	7/1/17	10:41	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
167	Yes	7/2/17	13:28	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
168	Yes	7/2/17	3:49	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
169	Yes	7/3/17	20:26	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
170	Yes	7/4/17	13:56	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
171	Yes	7/4/17	16:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
172	Yes	7/4/17	20:16	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
173	Yes	7/5/17	3:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
174	Yes	7/5/17	11:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
175	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
176	Yes	7/6/17	15:18	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
177	Yes	7/6/17	14:02	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
178	Yes	7/6/17	20:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
179	Yes	7/6/17	23:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
180	Yes	7/7/17	15:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
181	Yes	7/7/17	14:31	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	PG&E contractor
182	Yes	7/8/17	4:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
183	Yes	7/8/17	15:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
184	Yes	7/8/17	18:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
185	Yes	7/8/17	18:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
186	Yes	7/9/17	7:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
187	Yes	7/9/17	11:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
188	Yes	7/10/17	09:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
189	Yes	7/10/17	12:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
190	Yes	7/10/17	16:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
191	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
192	Yes	7/11/17	8:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
193	Yes	7/11/17	11:53	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
194	Yes	7/11/17	13:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
195	Yes	7/11/17	22:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
196	Yes	7/12/17	16:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
197	Yes	7/12/17	05:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
198	Yes	7/12/17	10:48	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
199	Yes	7/12/17	15:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
200	Yes	7/12/17	20:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
201	Yes	7/13/17	5:13	Contact From Object	N.A.	Other	Electric Facility	Other	bird material
202	Yes	7/13/17	07:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
203	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
204	Yes	7/14/17	17:54	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
205	Yes	7/15/17	14:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
206	Yes	7/15/17	14:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
207	Yes	7/15/17	20:16	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
208	Yes	7/15/17	21:01	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
209	Yes	7/16/17	10:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
210	Yes	7/16/17	11:59	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
211	Yes	7/16/17	12:10	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
212	Yes	7/16/17	17:07	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
213	Yes	7/17/17	07:39	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
214	Yes	7/17/17	10:00	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
215	Yes	7/17/17	18:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
216	Yes	7/18/17	11:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
217	Yes	7/18/17	21:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
218	Yes	7/18/17	07:39	Other	N.A.	N.A.	N.A.	Unknown	
219	Yes	7/18/17	11:45	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
220	Yes	7/19/17	5:52	Contact From Object	N.A.	Other	Electric Facility	Unknown	
221	Yes	7/19/17	09:33	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
222	Yes	7/19/17	17:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
223	Yes	7/20/17	20:57	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
224	Yes	7/20/17	01:46	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
225	Yes	7/20/17	04:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
226	Yes	7/20/17	13:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
227	Yes	7/20/17	17:00	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
228	Yes	7/21/17	13:27	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
229	Yes	7/21/17	20:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
230	Yes	7/22/17	12:25	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
231	Yes	7/22/17	14:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
232	Yes	7/22/17	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
233	Yes	7/23/17	09:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
234	Yes	7/23/17	16:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
235	Yes	7/23/17	18:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
236	Yes	7/23/17	19:41	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
237	Yes	7/24/17	14:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
238	Yes	7/24/17	16:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
239	Yes	7/24/17	19:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
240	Yes	7/24/17	21:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
241	Yes	7/25/17	15:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
242	Yes	7/25/17	19:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
243	Yes	7/26/17	06:55	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
244	Yes	7/28/17	14:02	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
245	Yes	7/28/17	16:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
246	Yes	7/28/17	19:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
247	Yes	7/29/17	13:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
248	Yes	7/29/17	13:28	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
249	Yes	7/29/17	14:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
250	Yes	7/29/17	17:56	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
251	Yes	7/29/17	18:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
252	Yes	7/29/17	20:45	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
253	Yes	7/30/17	09:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
254	No			Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
255	Yes	7/31/17	14:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
256	Yes	7/31/17	14:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
257	Yes	8/1/17	12:23	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
258	Yes	8/2/17	9:42	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
259	Yes	8/2/17	5:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
260	Yes	8/2/17	8:58	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
261	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
262	Yes	8/2/17	18:16	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
263	Yes	8/3/17	10:53	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
264	Yes	8/3/17	11:16	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
265	No			Unknown	N.A.	N.A.	N.A.	Unknown	
266	Yes	8/4/17	09:54	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
267	Yes	8/4/17	18:14	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
268	Yes	8/5/17	08:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
269	Yes	8/5/17	18:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
270	Yes	8/5/17	18:09	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
271	Yes	8/5/17	19:21	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
272	Yes	8/6/17	11:38	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
273	Yes	8/6/17	18:21	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
274	Yes	8/8/17	13:46	Contact From Object	N.A.	Other	Electric Facility	Human Error	
275	Yes	8/8/17	0:36	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
276	Yes	8/8/17	4:10	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
277	Yes	8/8/17	11:27	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
278	Yes	8/8/17	20:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
279	Yes	8/9/17	11:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
280	Yes	8/11/17	07:55	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
281	Yes	8/12/17	09:08	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	wire cut
282	Yes	8/13/17	13:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
283	Yes	8/14/17	6:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
284	Yes	8/14/17	23:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
285	Yes	8/14/17	07:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
286	Yes	8/15/17	19:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
287	Yes	8/16/17	20:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
288	Yes	8/17/17	2:33	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	pole cut down
289	Yes	8/17/17	15:15	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
290	Yes	8/18/17	17:09	Other	N.A.	N.A.	N.A.	Human Error	CIP contractor
291	Yes	8/19/17	11:31	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
292	Yes	8/19/17	21:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
293	Yes	8/20/17	11:38	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
294	Yes	8/21/17	15:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
295	Yes	8/21/17	19:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
296	Yes	8/22/17	14:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
297	Yes	8/24/17	6:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
298	Yes	8/25/17	9:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
299	Yes	8/26/17	7:10	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
300	Yes	8/26/17	20:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
301	Yes	8/26/17	20:53	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
302	Yes	8/27/17	18:11	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
303	Yes	8/27/17	20:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
304	Yes	8/27/17	22:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
305	Yes	8/28/17	6:32	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
306	Yes	8/28/17	8:36	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
307	Yes	8/28/17	9:14	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
308	Yes	8/28/17	10:07	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
309	Yes	8/28/17	13:55	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
310	Yes	8/28/17	14:06	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
311	Yes	8/28/17	14:23	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
312	Yes	8/28/17	14:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
313	Yes	8/28/17	23:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
314	Yes	8/29/17	6:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
315	Yes	8/29/17	10:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
316	Yes	8/29/17	10:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
317	Yes	8/29/17	12:49	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	PG&E contractor
318	Yes	8/29/17	15:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
319	Yes	8/30/17	16:17	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
320	Yes	8/30/17	18:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
321	Yes	8/30/17	22:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
322	Yes	8/30/17	22:39	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
323	Yes	8/31/17	6:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
324	Yes	8/31/17	11:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
325	Yes	8/31/17	11:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
326	Yes	8/31/17	21:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
327	Yes	8/31/17	22:50	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
328	Yes	9/1/17	6:09	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
329	Yes	9/1/17	8:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
330	No			Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
331	Yes	9/1/17	12:52	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
332	Yes	9/1/17	12:59	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
333	Yes	9/1/17	17:48	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
334	Yes	9/1/17	18:42	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
335	Yes	9/2/17	12:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
336	Yes	9/2/17	16:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
337	Yes	9/2/17	18:00	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
338	Yes	9/3/17	7:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
339	Yes	9/3/17	12:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
340	Yes	9/3/17	17:52	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
341	Yes	9/3/17	22:57	Contact Between Third Party Facility	N.A.	N.A.	N.A.	Weather	
342	Yes	9/4/17	0:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
343	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
344	Yes	09/04/17	6:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
345	Yes	9/5/17	1:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
346	Yes	9/5/17	6:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
347	Yes	9/5/17	7:20	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
348	Yes	9/5/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
349	Yes	9/5/17	17:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
350	Yes	9/6/17	19:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
351	Yes	9/6/17	20:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
352	Yes	9/8/17	4:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
353	Yes	9/8/17	17:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
354	Yes	9/8/17	21:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
355	Yes	9/9/17	18:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
356	Yes	9/10/17	1:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
357	Yes	9/10/17	16:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
358	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
359	Yes	9/11/17	8:50	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
360	Yes	9/11/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
361	Yes	9/12/17	9:24	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
362	Yes	9/12/17	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
363	Yes	9/14/17	11:02	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
364	Yes	9/14/17	12:09	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
365	Yes	9/14/17	14:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
366	Yes	9/15/17	14:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
367	Yes	9/17/17	15:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
368	Yes	9/17/17	17:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
369	Yes	9/18/17	13:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
370	Yes	9/18/17	15:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
371	Yes	9/18/17	18:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
372	Yes	9/18/17	19:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
373	Yes	9/18/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
374	Yes	9/19/17	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
375	Yes	9/20/17	2:06	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
376	Yes	9/20/17	8:41	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
377	Yes	9/21/17	8:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
378	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
379	Yes	9/23/17	9:16	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
380	Yes	9/23/17	14:17	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
381	Yes	9/24/17	2:13	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
382	Yes	9/24/17	7:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
383	Yes	9/24/17	16:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
384	Yes	9/25/17	19:49	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
385	Yes	9/26/17	17:44	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
386	Yes	9/27/17	9:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
387	Yes	9/27/17	12:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
388	Yes	9/27/17	19:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
389	Yes	9/28/17	18:28	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
390	Yes	9/29/17	2:01	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
391	Yes	9/30/17	15:08	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	Third-party caused
392	Yes	10/1/17	7:24	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
393	Yes	10/1/17	16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
394	Yes	10/1/17	23:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
395	Yes	10/2/17	2:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
396	Yes	10/2/17	7:07	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
397	Yes	10/2/17	12:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
398	Yes	10/2/17	14:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
399	Yes	10/2/17	16:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
400	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
401	Yes	10/3/17	17:48	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
402	No			Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
403	Yes	10/4/17	23:42	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
404	Yes	10/5/17	0:20	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
405	Yes	10/5/17	10:57	Contact From Object	N.A.	Other	Electric Facility	Other	bird's Nest
406	Yes	10/6/17	7:24	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
407	Yes	10/6/17	12:03	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
408	Yes	10/6/17	16:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
409	Yes	10/7/17	10:11	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
410	Yes	10/8/17	5:11	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
411	Yes	10/8/17	16:41	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
412	Yes	10/8/17	16:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
413	Yes	10/8/17	17:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
414	Yes	10/8/17	19:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
415	Yes	10/8/17	19:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
416	Yes	10/8/17	20:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
417	Yes	10/8/17	21:10	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
418	Yes	10/8/17	21:46	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
419	Yes	10/8/17	22:19	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
420	Yes	10/8/17	22:30	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
421	Yes	10/8/17	22:54	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
422	Yes	10/8/17	22:58	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
423	Yes	10/8/17	23:51	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
424	Yes	10/9/17	1:02	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
425	No			Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
426	Yes	10/9/17	1:25	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
427	Yes	10/9/17	1:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
428	Yes	10/9/17	1:45	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
429	Yes	10/9/17	2:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
430	Yes	10/9/17	4:36	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
431	Yes	10/9/17	12:05	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
432	Yes	10/10/17	13:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
433	Yes	10/10/17	16:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
434	Yes	10/10/17	16:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
435	Yes	10/11/17	11:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
436	Yes	10/11/17	16:41	Unknown	N.A.	N.A.	N.A.	Unknown	
437	Yes	10/13/17	8:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
438	Yes	10/13/17	10:27	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
439	Yes	10/13/17	19:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
440	Yes	10/13/17	22:19	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
441	Yes	10/14/17	8:37	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
442	Yes	10/14/17	14:43	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
443	Yes	10/15/17	13:15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
444	Yes	10/16/17	12:10	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
445	Yes	10/16/17	12:20	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
446	Yes	10/16/17	12:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
447	Yes	10/17/17	18:22	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
448	Yes	10/18/17	13:58	Contact From Object	N.A.	Vehicle	N.A.	Human Error	
449	Yes	10/20/17	5:59	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
450	Yes	10/20/17	6:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
451	Yes	10/20/17	9:06	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
452	Yes	10/20/17	13:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
453	Yes	10/20/17	13:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
454	Yes	10/20/17	14:00	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
455	Yes	10/21/17	15:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
456	Yes	10/21/17	16:05	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
457	Yes	10/23/17	19:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
458	Yes	10/23/17	21:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
459	Yes	10/24/17	15:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
460	Yes	10/26/17	10:53	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
461	Yes	10/28/17	15:26	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
462	Yes	10/28/17	20:08	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
463	Yes	10/31/17	18:56	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
464	Yes	10/31/17	21:02	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
465	Yes	11/6/17	9:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
466	Yes	11/6/17	15:06	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
467	Yes	11/8/17	07:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
468	Yes	11/8/17	14:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	P	Q	R	S	T	U	V	W	X
1	Outage			Field Observations					Notes (Optional):
2	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
469	Yes	11/11/17	11:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
470	Yes	11/12/17	19:44	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
471	Yes	11/14/17	07:43	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
472	Yes	11/17/17	09:53	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
473	Yes	11/20/17	08:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
474	Yes	11/20/17	20:05	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
475	Yes	11/21/17	11:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
476	Yes	11/22/17	13:44	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
477	Yes	11/23/17	16:29	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
478	Yes	11/24/17	10:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
479	Yes	11/25/17	6:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
480	Yes	11/26/17	10:10	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
481	Yes	11/27/17	06:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
482	Yes	11/27/17	11:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
483	Yes	11/28/17	15:49	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
484	Yes	11/29/17	17:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
485	No			Unknown	N.A.	N.A.	N.A.	Unknown	
486	Yes	12/12/17	4:40	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
487	Yes	12/13/17	12:13	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
488	Yes	12/14/17	1:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
489	Yes	12/14/17	17:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
490	Yes	12/16/17	7:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
491	Yes	12/16/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
492	Yes	12/16/17	13:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
493	Yes	12/16/17	16:03	Other	N.A.	N.A.	N.A.	Unknown	
494	Yes	12/19/17	7:05	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
495	Yes	12/19/17	16:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
496	Yes	12/19/17	19:45	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
497	Yes	12/20/17	07:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
498	No			Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
499	Yes	12/20/17	16:04	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
500	Yes	12/22/17	14:38	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
501	Yes	12/24/17	6:41	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
502	Yes	12/24/17	03:53	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
503	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
504									

CPUC Drop Downs

Human Error	Yes	Less Than .25 Acres	Communication Facility	Capacitor Bank
None	No	.26 - 9.99 Acres	Electric Facility	Conductor
Other		10 - 99 Acres	Pole	Fuse
Outside Force		100 - 299 Acres		Insulator
Unknown		300 - 999 Acres		Lightning Arrestor
Weather		1000 - 4999 Acres		Pole
		Greater than 5000 Acres		Guy/Span Wire
		Less than three (3) meters of linear travel		Other
		Structure Only		Protective Relay
				Crossarm
				Recloser
				Sectionalizer
				Splice/Clamp/Connector
				Switch
				Transformer
				Voltage Regulator