

From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>

Sent: Wednesday, September 9, 2020 11:41 AM

To: usrb@cpuc.ca.gov

Cc: [Redacted]

Subject: Electric Safety Incident Reported- PG&E Incident No: 200909-13638

*******CAUTION: This email was sent from an EXTERNAL source. Think before clicking links or opening attachments.*******

The Following information regarding this incident has been reported:

Reporting Date: 9/9/2020 11:35:36 AM

Incident Date: 9/8/2020 @ 9:55 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: 18th and Dolores San Francisco, San Francisco

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others: Residenc)
- Interruption? (Total Customers: 12, Total Hours: 5)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Line Failure (Other Cause: arc started a fire in basement)

Agencies on Scene: Police, Fire, Ambulance,

Facilities Affected:

- Utilities Facilities: 0
- Voltage (KV): 12
- Customer's Facilities: possibl 12

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: 9/8/2020 @ 9:55 p.m.
- Service Restored: 9/9/2020@ 3:50 a.m.

Summary: On September 8th, 2020 at approximately 21:30, PG&E was notified of an outage on the 022070406, SF E-0406 Distribution Circuit, impacting 12 customers, at 18th and Dolores due to a residential fire that is allegedly attributable to PG&E equipment. There are no known injuries or fatalities. Claims notified the on-call representative of damage to the third-party that is expected to exceed \$50K. PG&E is reporting this electric incident under the Property Damage criterion. This information is primary.