

The Following information regarding this incident has been reported:

Reporting Date: 5/16/2022 10:16:06 AM

Incident Date: 2/15/2022 @ 2:45 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Little Avenue and Vermont Street Gridley, Butte

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Fire (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Honcut 1101
- Voltage (KV): 12kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident EI220215A PG&E received a subrogation demand from Progressive Insurance regarding an incident that occurred on February 15, 2022, on the Honcut 1101 12kV overhead primary distribution circuit near Vermont Street and Little Avenue in Gridley. Progressive Insurance is allegedly attributing PG&E, stating a PG&E pole fire spread and damaged a mobile shower/bathroom trailer and shed resulting in over \$50,000 in property damages. This incident is being reported under the property damage criterion. This information is preliminary.