

The Following information regarding this incident has been reported:

Reporting Date: 5/26/2022 3:17:26 PM

Incident Date: 5/26/2022 @ 9:05 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Gold Country Lane and Grande Avenue Oroville, Butte

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Fire (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Tres Vias 1101
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident EI220526A On May 26, 2022, PG&E Law-Claims was notified of an electrical incident which occurred in the area of Gold Country Way and Grande Avenue in Oroville of Butte County. This area is served by Tres Vias 1101 12 kV Overhead primary Distribution Circuit. A PG&E Troubleshooter responded to a vegetation fire to ensure PG&E facilities were made safe. Upon arrival, the troubleshooter found the vegetation fire had caused property damage to a commercial garage. It was reported a service drop was damaged by a tree in the vicinity of the fire. Property damage is expected to exceed \$50,000. This incident is being reported under the property damage criterion. This information is preliminary.