

The Following information regarding this incident has been reported:

Reporting Date: 6/2/2022 8:07:36 AM

Incident Date: 5/25/2022 @ 6:30 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Avenue 12 and Trieste Drive Madera, Madera

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Fire (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Cassidy 2107
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident EI220525A On June 2, 2022, PG&E Law-Claims received a claim from Farmers Insurance alleging a structure fire On May 25, 2022, in the vicinity of Avenue 12 and Trieste Drive in Madera originated by sparks from the service drop and weatherhead of the residence. This location is served by Cassidy 2107 Overhead Distribution Circuit. The property damage has exceeded \$50,000. This incident is being reported under the property damage criterion. This information is preliminary.