

**The Following information regarding this incident has been reported:**

**Reporting Date:** 7/13/2022 12:24:03 PM

**Incident Date:** 7/13/2022 @ 12:35 a.m.

**Reported By:** [Redacted]

**Utility Name:** PG&E

**Phone Number:** [Redacted]

**Email Address:** [Redacted]

**Incident Location:** Virginia Street and West Frontage Road Berkeley, Alameda

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? No (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Metal Object (Other Cause: )

**Agencies on Scene:** Fire, Ambulance,

**Facilities Affected:**

- Utilities Facilities: El Cerrito G 1109
- Voltage (KV): 12 kV
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** CPUC Electric Incident EI220713A On July 13, 2022, at 0035 hours, PG&E received notification of an outage in the area of Virginia Street and West Frontage Road, Berkeley of Alameda County. The area is served by the El Cerrito G 1109 12 kV Primary Overhead Distribution Circuit. A sailboat capsized near Berkeley Marina and the mast made contact with PG&E primary lines resulting in a third-party individual receiving injuries from the electrocution. The third-party is expected to be hospitalized. This incident is being reported under the Injury criterion. This information is preliminary.