

The Following information regarding this incident has been reported:

Reporting Date: 7/29/2022 1:59:08 PM

Incident Date: 2/11/2021 @ 1:45 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Spreckels Boulevard and Spreckels Lane Salinas, Monterey

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Fire (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Reservation Rd 1102
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident EI210211A - On June 13, 2022, PG&E received notice of a lawsuit regarding a residential structure fire that occurred on February 11, 2021, at approximately 0145 hours near Spreckels Lane and Spreckels Blvd in Salinas. This property is serviced by the Reservation Road 1102 12kV Overhead Primary Distribution circuit. The lawsuit claims \$186,130.05 in property damage to the customer's home. The lawsuit identifies the property damages are a result of a power surge caused by PG&E. This incident is being reported under the Property Damage criterion based on the claimed damages exceeding \$50,000. This information is preliminary.