

**The Following information regarding this incident has been reported:**

**Reporting Date:** 9/2/2022 3:29:03 PM

**Incident Date:** 8/31/2022 @ 4:00 p.m.

**Reported By:** [Redacted]

**Utility Name:** PG&E

**Phone Number:** [Redacted]

**Email Address:** [Redacted]

**Incident Location:** Belmont Avenue and North Highland Avenue Sanger , Fresno

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Falling Tree (Other Cause: )

**Agencies on Scene:**

**Facilities Affected:**

- Utilities Facilities: Sanger 1114
- Voltage (KV): 12kV
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** CPUC PG&E Electrical Incident EI220831A - On August 31, 2022 at approximately 1604 hours, a vegetation fire occurred in the area of Belmont Avenue and North Highland Avenue in Sanger, a non-HFTD area. This area is serviced by the Sanger 1114 12kV primary overhead distribution circuit. A eucalyptus tree branch fell onto the primary distribution circuit. The primary conductor fell onto a metal fence along a private roadway and ignited a small vegetation fire. The vegetation fire was contained to 1.5 acres by CALFIRE. This incident resulted in an outage affecting 327 customers. Power was restored to all 327 customers by 0145 hours on September 1, 2022. This incident resulted in property damages to two residential properties estimated to exceed \$50,000. This incident is being reported under the property damage criterion. This information is preliminary.