

**The Following information regarding this incident has been reported:**

**Reporting Date:** 9/5/2022 8:36:05 PM

**Incident Date:** 9/5/2022 @ 2:00 p.m.

**Reported By:** [Redacted]

**Utility Name:** PG&E

**Phone Number:** [Redacted]

**Email Address:** [Redacted]

**Incident Location:** Leisure Town Road and Denton Street Vacaville , Solano

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? No (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? Yes

**Cause of Incident:** Other (Other Cause: Train possibly clipped conductor )

**Agencies on Scene:**

**Facilities Affected:**

- Utilities Facilities: Peabody 2105
- Voltage (KV): 21kV
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** CPUC PG&E Electrical Incident EI220905A - On September 5, 2022 at 1402 hours, the Peabody 2105 21kV primary overhead distribution circuit experienced a sustained outage affecting 5870 customers. The outage was caused by a common neutral wrapping around the primary conductor in the area of Leisure Town Road and Denton Street in Vacaville, a non-HFTD. The portion of Peabody 2105 conductor involved in the incident is suspended over train tracks. It is believed the common neutral was struck by a passing train, causing it to wrap around the primary conductor. This incident resulted in a small vegetation fire that was contained to less than a quarter acre. All 5870 customers were restored by 1531 hours. PG&E received four reputable media inquiries into this incident within six hours of the initial outage. This incident is being reported under the media criterion. This information is preliminary.