

The Following information regarding this incident has been reported:

Reporting Date: 11/25/2020 9:28:00 AM

Incident Date: 10/1/2020 @ 12:05 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Lane Drive and Walden Drive Madera, Madera

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Falling Branch (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Storey 1111
- Voltage (KV):
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 p.m.
- Service Restored: @ 00:00 a.m.

Summary: On November 25, 2020, PG&E Law-Claims received a property damage claim in excess of \$50,000 from a customer on Lane Drive in Madera. The claim alleges that a structure was damaged on October 1, 2020 due to vegetation contacting PG&E facilities causing a wires down incident and a fire. The claim alleges that the structure was damaged due to the resulting fire. The structure is served by the Storey 1111 Distribution Circuit. There are no known injuries or fatalities. PG&E is reporting this electric incident under the property damage criterion. This information is preliminary.