

**The Following information regarding this incident has been reported:**

**Reporting Date:** 12/1/2020 6:08:22 PM

**Incident Date:** 6/18/2020 @ 3:25 p.m.

**Reported By:** [Redacted]

**Utility Name:** PG&E

**Phone Number:** [Redacted]

**Email Address:** [Redacted]

**Incident Location:** Ave 22 and Rd 15-1/2 Chowchilla, Madera

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Unknown (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Chowchilla 1101
- Voltage (KV): 12
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** On December 1, 2020, PG&E received a property damage claim for \$122,000 for a fire that resulted in the loss of a structure. The claim alleges that PG&E equipment caused a structure fire near Avenue 22 and Road 15 1/2 in Chowchilla on June 18, 2020 at approximately 1500 hours. According to the responding troubleman, a customer-owned pole holding the PG&E service drop and meter burned. The service drop was on the ground and energized upon arrival. The property is served by the Chowchilla 1101 Overhead Distribution Circuit and the fire impacted the sole customer. PG&E is reporting this under the Property Damage criteria. This information is preliminary.