

The Following information regarding this incident has been reported:

Reporting Date: 12/2/2020 5:32:40 PM

Incident Date: 11/23/2020 @ 12:50 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Navajo Drive and North 1st Street Salinas, Monterey

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Salinas 1103
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: On December 2, 2020, PG&E received a notice of a potential claim for property damage exceeding \$50,000, for a structure fire that took place on November 23, 2020 at Navajo Drive and North 1st Street in Salinas. The responding PG&E troubleman arrived on-scene and observed a structure fire and a downed service drop. As the troubleman was winding up the service drop, he observed that the neutral was broken. PG&E is reporting this under the Property Damage criteria. This information is preliminary.