

The Following information regarding this incident has been reported:

Reporting Date: 1/22/2022 5:38:04 PM

Incident Date: 1/22/2022 @ 6:00 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Doncaster Place and Thornhill Drive Oakland, Alameda

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Falling Branch (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Oakland K 1102
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electric Incident EI220122A. On January 22, 2022 PG&E Law Claims received a report of property damage to a residence that occurred on January 22, 2022 at approximately 0600 hours in the vicinity of Doncaster Place and Thornhill Drive in Oakland. The associated distribution circuit is the overhead primary Oakland K 1102 12kV. The report is alleging that damage to the overhead service drop as a result of a fallen tree branch resulted in a fire to the residence. Property damage is expected to exceed \$50,000. This information is being reported under the Property Damage criterion. This information is preliminary.