

The Following information regarding this incident has been reported:

Reporting Date: 2/8/2022 10:06:18 AM

Incident Date: 1/24/2022 @ 00:00 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Meadow Creek Drive and Skyward Road Butte Meadows, Butte

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Oro Fino 1102
- Voltage (KV): 12kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident ? EI220124B - On January 24, 2022 PG&E Law Claims was notified of a property damage incident in the vicinity of Meadow Creek Drive and Skyward Road in Butte Meadows. A cabin serviced by Oro Fino 1102 12 kV overhead primary distribution circuit was damaged in a structure fire on an unknown date and time. The damage to the cabin is expected to exceed \$50,000. The property owner is allegedly attributing PG&E for the fire, reporting the fire was caused when a tree fell onto the service connect and sparked a fire at the weatherhead. This incident is being reported under the property damage criterion. This information is preliminary.