

**The Following information regarding this incident has been reported:**

**Reporting Date:** 4/7/2022 1:54:44 PM

**Incident Date:** 4/6/2022 @ 9:30 a.m.

**Reported By:** [Redacted]

**Utility Name:** PG&E

**Phone Number:** [Redacted]

**Email Address:** [Redacted]

**Incident Location:** Borega Lane and Cherry Blossom Place Nipomo, San Luis Obispo

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Fire (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Mesa 1103
- Voltage (KV): 12
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: 4/6/2022 @ 9:30 a.m.
- Service Restored: 4/6/2022@ 00:00 a.m.

**Summary:** CPUC PG&E Electric Incident EI220406A. On April 6, 2022 PG&E responded to a vegetation fire in the area of Borega Lane and Cherry Blossom Place in Nipomo, San Luis Obispo County. While on scene, a troubleman observed a downed conductor. This area is served by the Mesa 1103 12 kV Overhead Distribution Circuit. On April 7, 2022, PG&E Law-Claims reported they anticipate potential claims exceeding \$50,000. This information is being reported under the Property Damage criterion. This information is preliminary.