

The Following information regarding this incident has been reported:

Reporting Date: 9/22/2022 5:33:09 PM

Incident Date: 9/18/2022 @ 12:10 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: East Homestead Road and Peacock Avenue Sunnyvale, Santa Clara

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause: broken cross arm)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Wolfe 1106
- Voltage (KV): 12kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident - EI220918A - On September 18, 2022 at approximately 1209 hours, a residential structure fire occurred in the area of East Homestead Road and Peacock Avenue in Sunnyvale, a Non-HFTD. This area is serviced by the Wolfe 1106 12kV overhead primary distribution circuit. This incident resulted in an outage affecting 1,940 customers. All customers were restored by 0145 hours on September 19, 2022. On September 22, 2022, PG&E Law-Claims received a property damage claim exceeding \$50,000. The claim alleges that a high voltage line fell on the roof of the home and caused a fire. This incident is being reported to the CPUC under the property damage criterion. This information is preliminary.