

The Following information regarding this incident has been reported:

Reporting Date: 12/27/2022 11:26:12 AM

Incident Date: 12/12/2022 @ 1:50 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: San Ignacio Avenue and Via Del Oro San Jose , Santa Clara

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Edenvale 2107
- Voltage (KV): 21kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident EI221212A. On December 12, 2022, at approximately 1350 hours, PG&E was notified of a commercial structure fire in the area of Via Del Oro and San Ignacia Avenue in San Jose (a non-HFTD). The responding troubleshooter deenergized the commercial building and noted the only damaged equipment identified was customer owned equipment; no PG&E equipment was damaged. This area is serviced by the Edenvale 2107 21kV underground primary distribution circuit. The fire caused over \$50,000 in property damages. On December 21, 2022, PG&E law claims received a notice of potential claim. The cause of the fire is unknown at this time. This incident is being reported under the property damage criterion. This information is preliminary.