

The Following information regarding this incident has been reported:

Reporting Date: 1/3/2023 5:40:16 PM

Incident Date: 1/1/2023 @ 5:35 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Wolfe Glen Way and Wolfe Grade Kentfield, Marin

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause: Unbalanced voltage)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: San Rafael 1107
- Voltage (KV): 12kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electric Incident EI230101A On January 3, 2023, PG&E Law-Claims received a customer claim for property damage in excess of \$50,000. The customer is located in the area of Wolfe Glen Way and Wolfe Grade in Kentfield of Marin County, a non-HFTD. The area is served by the San Rafael 1107 12kV underground distribution circuit. The claim alleges that on January 1, 2023, the customer was provided unbalanced voltage resulting in a structure fire. This incident is being reported under the property damage criterion. This information is preliminary.