

The Following information regarding this incident has been reported:

Reporting Date: 2/28/2023 4:52:05 PM

Incident Date: 7/10/2022 @ 7:40 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Driftwood and Church Street Bodega Bay, Sonoma

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Salmon Creek 1101
- Voltage (KV): 12kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electrical Incident EI220710B On February 28, 2023, PG&E Law-Claims received a property damage claim exceeding \$50,000. The customer is located in the area of Driftwood and Church Street in Bodega Bay, Sonoma County, a non-HFTD. The area is served by the Salmon Creek 1101 12kV overhead distribution circuit. The claim alleges that on July 10, 2022, PG&E electrical equipment energized a non-electrical cable attached to the exterior of a home and caused a residential structure fire. This incident is being reported under the property damage criterion. This information is preliminary.