

The Following information regarding this incident has been reported:

Reporting Date: 2/21/2023 11:44:12 PM

Incident Date: 2/21/2023 @ 6:10 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: S MacDonough Ave and E Nebraska Ave Reedley, Fresno

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Parlier 1104
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electric Incident EI230221A On February 21, 2023, at 1811 hours, PG&E responded to a structure fire near the intersection of S MacDonough Ave and E Nebraska Ave, Reedley, a non-HTFD. The location is served by the Parlier 1104 12kV overhead distribution circuit. PG&E personnel on scene reported a pole and transformer fell on a house and the house was on fire. The fire department extinguished the fire, there were no injuries as a result of this event. This information is being reported under the property damage criterion as damages are expected to exceed \$50,000. This information is preliminary.