

The Following information regarding this incident has been reported:

Reporting Date: 6/28/2023 5:51:04 PM

Incident Date: 6/27/2023 @ 3:55 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: 29th Avenue and Moraga Street San Francisco, San Francisco

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause: Voltage issue)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: 21ST AVENUE 0401
- Voltage (KV): 4
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electric Incident EI230627A On June 27, 2023, at 1600 hours, PG&E was notified of high voltage in the area of 29th Avenue and Moraga Street, San Francisco of San Francisco County, a non HFTD. This area is served by the 21ST Avenue 0401 4kV overhead distribution circuit. A short time later, the fire department requested PG&E respond to a structure fire in the same area. PG&E responded and disconnected service to the structure and the fire department extinguished the fire. Damage to the structure is estimated to exceed \$50,000. This incident is being reported under the property damage criterion. This information is preliminary.