

The Following information regarding this incident has been reported:

Reporting Date: 8/28/2023 2:20:21 PM

Incident Date: 1/10/2023 @ 8:00 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: W. Cadillac Avenue and S. Amador Avenue Coalinga, Fresno

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Tree/Line Contact (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Schindler 1114
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electric Incident - EI230110B - On January 11, 2023, at approximately 1315 hours, PG&E was notified of an outage in the area of W. Cadillac Avenue and S. Amador Avenue in Coalinga, of Fresno County, a non-HFTD. This area is served by the Schindler 1114 12kV overhead distribution circuit. On August 28, 2023, PG&E Law-Claims received a claim exceeding \$50,000, alleging a power surge caused damage to electrical equipment due to the lines contacting a tree. This incident is being reported under the property damage criterion. This information is preliminary.