

The Following information regarding this incident has been reported:

Reporting Date: 9/16/2023 12:00:28 PM

Incident Date: 5/5/2023 @ 7:00 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Lupin Lane and Rosewood Drive Atherton, San Mateo

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Belle Haven 0407
- Voltage (KV): 4
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electrical Incident - On May 5, 2023, a PG&E troubleshooter responded to the vicinity of Lupin Lane and Rosewood Drive in Atherton, of San Mateo County, a non-HFTD. The area is served by the Belle Haven 0407 4kV overhead distribution circuit. The troubleshooter found a tree on secondary main line in the rear of the home and created an EC Tag for a tree crew and PG&E repair crew. On May 6, 2023, at 0535 hours, Menlo Park Fire Department requested PG&E assistance for a structure fire at the incident location. PG&E gas & electric services responded to the location. Law-Claims has received a claim exceeding \$50,000.00. This incident is being reported under the property damage criterion. This information is preliminary.