

The Following information regarding this incident has been reported:

Reporting Date: 3/2/2024 10:30:42 AM

Incident Date: 3/1/2024 @ 8:00 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Spring Mountain Road and Langtry Road St. Helena, Napa County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Line Failure (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Silverado 2105
- Voltage (KV): 21
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electric Incident - EI240301A - On March 1, 2024, PG&E was notified of an outage in the area of Spring Mountain Road and Langtry Road, in St. Helena of Napa County, a tier-3 HFTD. This area is served by the Silverado 2105 21kV Overhead Distribution circuit. A PG&E troubleshooter responded and discovered a burned structure. Preliminary information indicates that one phase of wire came down and landed on the structure. This incident is being reported under the property damage criterion as property damage is expected to exceed \$50,000. This information is preliminary.