

**From:** [webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov) <[webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov)>

**Sent:** Thursday, November 8, 2018 4:09:50 PM

**To:** [usrb@cpuc.ca.gov](mailto:usrb@cpuc.ca.gov)

**Cc:** Allen, Meredith

**Subject:** Electric Safety Incident Reported- Pacific Gas & Electric Incident No: 181108-9002

**The Following information regarding this incident has been reported:**

**Reporting Date:** 11/8/2018 6:06:53 PM

**Incident Date:** 11/8/2018 @ 6:15 a.m.

**Reported By:** Meredith Allen, Sr. Director - Regulatory Relations

**Utility Name:** Pacific Gas & Electric

**Phone Number:** (415)828-5765

**Email Address:** [MEAE@pge.com](mailto:MEAE@pge.com)

**Incident Location:** Pulga Rd. Pulga,, Butte County

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? No (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? Yes
- Media Coverage? No

**Cause of Incident:** Unknown (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Caribou-Palermo
- Voltage (KV): 115kV
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** On November 8, 2018, at approximately 0615 hours, PG&E experienced an outage on the Caribou-Palermo 115 kV Transmission line in Butte County. In the afternoon of November 8, PG&E observed by aerial patrol damage to a transmission tower on the Caribou-Palermo 115 kV Transmission line, approximately one mile north-east of the town of Pulga, in the area of the Camp Fire. This information is preliminary.