

EXHIBIT A

Year	Guidance	% Captured of All HFTD Tree Over Strike in Cells >70th Percentile ¹	% Captured of All HFTD Veg. Outages in Cells > 70th Percentile ¹ (2008-2020)	PSPS Total Events	% Difference Total Events from Baseline	Total Customer-Hours ^{2,3,4}	% Difference from Baseline - Total Customer-Hours ^{2,3,4}	Total Customer Impact ^{2,3}	% Difference from Baseline - Total Customer Impact ^{2,3}	Avg. Event Duration ⁴	% Difference from Baseline - Avg. Event Duration ^{4,5}	Avg. Customer Impact ^{2,3}	% Difference from Baseline - Avg. Customer Impact ^{2,3,5}	Max. Event Customer Impact ^{2,3}	% Difference from Baseline - Max. Event Customer Impact ^{2,3}
2019	2019 Actual Events (Transmission & Distribution Scope Impacts)	63%	62%	8	100%	88,197,922	209%	2,014,353	170%	27	-27%	251,794	35%	967,705	205%
2019	2019 Actual Events (Distribution Only Scope Impacts)	63%	62%	8	100%	76,969,720	170%	1,833,300	146%	27	-27%	229,163	23%	705,400	122%
2019	2019 Based on 2020 Baseline (current models)	66%	70%	4	-	28,512,084	-	745,903	-	37	-	186,476	-	317,455	-
2019	2020 Baseline + P1/P2 Trees	69%	73%	4	0%	30,454,154	7%	786,101	5%	37	0%	196,525	5%	320,951	1%
2019	2020 Baseline +>70th Percentile - Sum Tree Over Strike	94.2%	89.7%	5	25%	36,658,248	29%	874,563	17%	36	-3%	174,913	-6%	341,905	8%
2019	2020 Baseline +>70th Percentile - Sum Tree Over Strike + P1/P2 Trees	94.4%	90.1%	5	25%	36,955,898	30%	881,539	18%	36	-3%	176,308	-5%	341,976	8%

1. **% Captured of HFTD Tree Over Strike, Vegetation Caused Outages 2008-2020**, based on cells >70th percentile OPW based on input sustained wind speed of 20mph matching minimum fire potential conditions, + net new cells >70th percentile tree over strike for the potential overstrike criteria study, + net new cells containing P1/P2 trees based on the trees outstanding for the 10/26/19 event for the P1/P2 criteria study. 2019 Actual Events based on 2019 OPW Model Version, and 2020 guidance studies based on enhanced 2020 OPW Model version. Note, 2021 OPW Model version currently under development ahead of 2021 fire season.
2. **Customer counts** are distribution service points for guidance studies and are estimated at **circuit level counting all customers with HFTD** secondary transformers on a circuit, and do not include customer impacts from Transmission PSPS.
3. **Customer-Hours** impacts is based on **event duration** multiplied by the **customer count** for each event and then summed across all events to calculated Total Customer-Hours.
4. **Event duration** for the guidance study rows is the event weather duration calculated based on the time delta between the first and last hour of the event that are defined to be exceeding PSPS guidance. Some customers will experience shorter weather event duration than this, and if the line is able to be patrolled and restored quickly (for example with no extensive damage found), may experience total outage duration less than the event weather duration. **Event duration** for the actual 2019 events is calculated based on subtracting the Restoration Durations as measured by Customer Average Interruption Duration Index (CAIDI) from the Event Duration as measured in CAIDI.
5. Decrease in **average customer impact** and **average event duration** for the addition of the >70th percentile tree over strike criteria to the 2020 baseline is due to the addition of a fifth PSPS that is smaller and shorter in duration compared to the existing four events meeting baseline event criteria.