

**The Following information regarding this incident has been reported:**

**Reporting Date:** 8/17/2023 6:59:03 PM

**Incident Date:** 12/12/2022 @ 8:40 a.m.

**Reported By:** [Redacted]

**Utility Name:** PG&E

**Phone Number:** [Redacted]

**Email Address:** [Redacted]

**Incident Location:** Meernaa Avenue and Spring Lane Fairfax, Marin

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Other (Other Cause: Unbalanced Voltage)

**Agencies on Scene:**

**Facilities Affected:**

- Utilities Facilities: San Rafael 1108
- Voltage (KV): 12kV
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** CPUC Electric Incident EI221212C On August 17, 2023, PG&E Law-Claims received a property damage claim in excess of \$50,000. The customer is located in the vicinity of Meernaa Avenue and Spring Lane in Fairfax, of Marin County, a Tier 3-HFTD. The area is served by the San Rafael 1108 12kV overhead distribution circuit. The claim alleges that on December 12, 2022, PG&E electrical equipment was the cause of a residential structure fire. This incident is being reported under the property damage criterion. This information is preliminary.