

The Following information regarding this incident has been reported:

Reporting Date: 1/5/2021 3:48:40 PM

Incident Date: 5/27/2018 @ 4:45 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Pinon Avenue and Knobcone Avenue Anderson, Shasta

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Tree/Line Contact (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Anderson 1101
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: On January 5, 2021, PG&E received a property damage claim exceeding \$50,000 for a fire that resulted in damage to their attic. The claim alleges that PG&E equipment caused a structure fire near Pinon and Knobcone Avenue in Anderson on May 27, 2018 at approximately 1600 hours. The property is served by the Anderson 1101 Overhead Distribution Circuit. PG&E is reporting this under the Property Damage criteria. This information is preliminary.