

The Following information regarding this incident has been reported:

Reporting Date: 3/2/2021 4:00:00 PM

Incident Date: 8/9/2020 @ 00:00 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: W. Washington Street east of Highway 101 Eureka, Humboldt

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities:
- Voltage (KV): 12kV
- Customer's Facilities: Eureka A-1107

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: On March 2, 2021, PG&E received a property damage claim from a third-party telecommunications company for in an incident involving a pole fire that occurred on August 9, 2020 at approximately 0005 hours. The alleged damage to the third-party equipment in addition to the damage sustained to PG&E equipment exceeds \$50,000. The incident occurred on West Washington Street east of Highway 101 in Eureka. This location is served by the Eureka A-1107 12 KV circuit. PG&E is reporting this under the Property Damage criteria. This information is preliminary.