

The Following information regarding this incident has been reported:

Reporting Date: 3/22/2021 11:59:28 PM

Incident Date: 3/22/2021 @ 4:30 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: E Tennessee and E Colorado Fairfield, Solano

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause: Wire Down)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: SUISUN-1102
- Voltage (KV):
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: On March 22, 2021, at approximately 16:30 hours, PG&E responded to a report of a structure fire near E Tennessee and E Colorado in Fairfield, CA. At the location, PG&E observed a Phase 1 wire down in the area of the fire ,and saw that the fire had caused an extensive damage to the house. PG&E is reporting this incident under the Property Damage reporting criteria due to the wire down and extensive damage to the house possibly exceeding \$50,000. This information is preliminary.