

**The Following information regarding this incident has been reported:**

**Reporting Date:** 5/17/2021 1:09:23 PM

**Incident Date:** 9/9/2020 @ 10:45 a.m.

**Reported By:** [Redacted]

**Utility Name:** PG&E

**Phone Number:** [Redacted]

**Email Address:** [Redacted]

**Incident Location:** Buckthorn Murphys, Calaveres

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** No Cause Selected (Other Cause: )

**Agencies on Scene:**

**Facilities Affected:**

- Utilities Facilities: Stanislaus 1701
- Voltage (KV): 17 kV
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** EI200909A - CPUC Electric Incident - Murphys Property Damage: On May 17, 2021 PG&E received a property damage claim for \$81,000 alleging that PG&E equipment caused a fire resulting in damage to an air conditioner, sewer pump, 2 vehicles, and landscaping on September 09, 2020 at approximately 1045 hours near Buckhorn Drive & Laurel Lane in Murphys when power was restored after a PSPS event. The location is served by the Stanislaus 1701 17 kV UG Distribution Circuit. PG&E is reporting this under the property damage criteria. This information is preliminary.