

The Following information regarding this incident has been reported:

Reporting Date: 6/3/2021 9:57:57 AM

Incident Date: 6/2/2021 @ 12:40 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Sutter Road McKinleyville, Humboldt

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Vehicle (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Janes Creek 1101
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: On June 2, 2021, PG&E dispatched a troubleman to Sutter Road and Church Ave in McKinleyville after receiving a call from Cal Fire regarding a structure fire. This location is served by the Janes Creek 1101 12kV Overhead Distribution Circuit. Upon arrival the troubleman observed the service drop low and the service neutral compression sleeve was pulled apart. The Cal Fire investigator advised the troubleman that possibly a garbage or large box truck made contact with the overhead service. PG&E is reporting this incident under the Property Damage criteria after determining that the damage is expected to exceed \$50,000. This information is preliminary.