

The Following information regarding this incident has been reported:

Reporting Date: 6/22/2021 5:31:12 PM

Incident Date: 6/6/2021 @ 00:00 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: 6700 Block of Foxen Canyon Road Los Olivos, Santa Barbara

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities:
- Voltage (KV):
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electrical Incident - Property Damage - EI210606A - On June 22, 2021, PG&E's Law-Claims Department received a Notice of Communal Inspection for a fire incident that allegedly occurred on the 6700 block of Foxen Canyon Road in Los Olivos on June 6, 2021. The notice alleges that PG&E equipment may be responsible for the cause of the fire. The property damage value is estimated to exceed \$50,000. The address is served by the Zaca 1101 12kV Overhead Distribution Circuit. The portion of the circuit at the incident location did not appear to have any outages on the day of the incident. PG&E retained the customer electric meter as evidence. PG&E is reporting this incident under the Property Damage criteria. This information is preliminary.