

EIR or NR Number: EI210710A

Date and Time of Incident: 7/10/2021 10:07:00 PM

Section 2 - Physical Information

Incident Location: Fruitvale Rd & Dobbins St

Incident City: Vacaville

Section 3 - Incident Type

EIR Reporting Criteria: Property Damage

Section 4 - Facility Information

Facility Information: ;#UG Primary;#

Section 5 - EIR Reportable Incident Details

Date and Time CPUC Notified: 7/11/2021 1:32:00 AM **CPUC Notification Method:** Phone

Section 9 - Outage Involved: Yes

Actual Date and Time of Restoration: 7/10/2021 11:46:00 AM

Section 10 - Other Information for CPUC Web Site Reporting

Agencies on Scene:

Police: No **Fire:** Yes **Ambulance:** No **Media:** No

Dig-In: No

CPUC Summary:

CPUC Electrical Incident, EI210710A - Property Damage: On July 10, 2021 at approximately 2210 hours an underground transformer blew and caught fire at Fruitvale Road and Dobbins Street in Vacaville resulting in a sustained outage to 959 customers on the Vacaville-1111 12 kV Distribution Circuit. The responding troubleman observed two nearby vehicles caught fire and two additional vehicles sustained transformer oil spatter. The total combined damages are expected to exceed \$50K. This information is preliminary.