

The Following information regarding this incident has been reported:

Reporting Date: 8/25/2021 6:54:05 PM

Incident Date: 8/25/2021 @ 3:00 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Placer Rd Redding, Shasta

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: No Cause Selected (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Girvan 1101
- Voltage (KV): 12 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident ? EI210825A - On August 25, 2021 at approximately 1500 hours, a PG&E third-party contractor was conducting work on PG&E's Girvan 1101 12kV Distribution Circuit near Placer Road and Muletown Road in Redding. The crew was installing a new pole and a new service. While cutting to remove the old service, the crew observed sparks from the service ignite a fire. The crew attempted to extinguish the fire but was unsuccessful. The fire grew to approximately 9.2 acres and was eventually extinguished by CalFire. The fire damaged a detached garage to a residence, a contractor pickup truck, a contractor water buffalo and PG&E poles. This incident is being reported under the property damage criterion due to damages anticipated to exceed \$50,000. PG&E is not aware of any injuries or fatalities. PG&E is reporting this incident out of an abundance of caution. This information is preliminary.

