

# **Exhibit EE**

# North Valley

## Outage Report

Report Printed Wed Jul 14 14:51:01 PDT 2021		
Date From	Date To	Outage Type Both
OutNum 21-0089207	Equipment Type	Equip Condition
Equipment Involved	Equipment Cause	Equipment Supplemental
Outage Level	Outage Interval	Fault Type
Action Required Both	Active Both	Circuit
EquipID	Fire Mitigation No	District

[Export To Excel](#)

## Unplanned Outages

### Paradise

<b>Circuit</b>	102211101, BUCKS CREEK-1101	<b>Event Log</b>	21-0089207
<b>Type</b>	Unplanned	<b>Weather</b>	Clear;32-90F
<b>Customers</b>	<a href="#">CESO</a> 4 <a href="#">CEMO</a> 0 <a href="#">ADJ</a> 3 <a href="#">Initial</a> 2	<b>Customer Minutes</b>	<a href="#">Sus</a> 460 <a href="#">Mom</a> 0 <a href="#">Adj</a> 460 <a href="#">CAIDI</a> 153
<b>Active</b>	YES	<b>Fault Type</b>	Line to Line
<b>Interval</b>	Sustained	<b>Action Required</b>	No
<b>EquipID</b>	17733	<b>Construction Type</b>	OH
<b>Equipment Type</b>	Fuse	<b>OIS Outage#</b>	1403761
<b>Equipment Condition</b>	Conductor, Overhead, Normal	<b>Targets</b>	
<b>Crew Notified Time</b>		<b>Supervisor Notified</b>	
<b>Equipment Address</b>	CRESTA DAM TAP W/O SW 17183	<b>Fire Mitigation</b>	No
<b>Fault Location</b>	1ST SPAN LD SIDE OF FUCO 17733		
<b>Previous Switching Details</b>	VEG FIRE IN AREA		
<b>Action Description</b>		<b>Wire Down Energized</b>	No
<b>Cause</b>	Vegetation, Tree - fell into line	<b>No Access Reason</b>	
<b>Multi Damage Location</b>	No	<b># of Operations</b>	
<b>Counter Read</b>		<b>Created By</b>	██████
<b>Outage Level</b>	Distribution Circuit	<b>Last Updated By</b>	██████
<b>FNL</b>	07/13/21 16:40	<b>Reviewed By</b>	Not Required
<b>End Date</b>		<b>Reviewed By Date</b>	

  

Date	Description	Customers Restored
07/13/21 16:40	FUSE 17733 OPEN- ██████ FOUND FUCO 17733 #1 AND #2 BLOWN OPENED REMAINING AND TAGGED MOL -TREE IN THE LINE - GRASS FIRE- CALLED CPUC- D.O. NOTIFIED OF FUSES BLOWN AT 2250; ██████ HAD ALSO REPORTED THAT THERE WERE MULTIPLE CONSTRUCTION CREWS IN THE AREA WORKING ON THE BRIDGE AND TUNNEL ALL NEAR THE TROUBLE AREA, TOOK AN EXTRA 2 HOURS TO GET AROUND THEM TO GET TO THE LOCATION	0
07/13/21 20:30	SWITCH 941 OPEN & T/MOL, PER TMAN ██████ & ██████; PER CAL FIRE REQUEST TO OPEN SWITCH FOR SAFETY DUE TO A FIRE IN THE AREA	-1