

The Following information regarding this incident has been reported:

Reporting Date: 3/24/2023 1:47:23 PM

Incident Date: 7/24/2021 @ 4:20 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: 3rd Avenue and Moller Avenue Orland, Tehama County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause: Pole)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Capay 1101
- Voltage (KV): 12kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electric Incident EI210724C On March 24, 2023, PG&E Law-Claims received a claim in excess of \$50,000. The customer is located in the vicinity of 3rd Avenue and Moller Avenue in Orland, of Tehama County, a non-HFTD. The area is served by the Capay 1101 12kV overhead distribution circuit. The claim alleges that on July 24, 2021, a PG&E pole fell and energized primary lines ignited a vegetation fire causing damage to a pomegranate orchard. This incident is being reported under the property damage criterion. This information is preliminary.