

The Following information regarding this incident has been reported:

Reporting Date: 4/4/2023 6:25:28 PM

Incident Date: 2/24/2023 @ 8:25 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Coyote Ridge Road and Road 426 Oakhurst, Madera

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Coarsgold 2102
- Voltage (KV): 21
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electric Incident EI230224B On February 24, 2023, at 2030 hours, PG&E records indicate an outage occurred in the vicinity of Coyote Ridge Road and Road 426 in Oakhurst, of Madera County, a Tier 3-HFTD. The area is served by the Coarsegold 2102 21kV overhead distribution circuit. On February 25, 2023, at 0100 hours, a PG&E troubleshooter was dispatched to a support a structure fire in the same area of the outage. The troubleshooter arrived and observed the weatherhead of the residence on the ground and an active structure fire. On April 4, 2023, PG&E Law Claims received a claim in excess of \$50,000, alleging PG&E equipment caused the structure fire. This incident is being reported under the property damage criterion. This information is preliminary.