

**The Following information regarding this incident has been reported:**

**Reporting Date:** 12/29/2023 11:01:26 AM

**Incident Date:** 10/29/2023 @ 11:40 a.m.

**Reported By:** [Redacted]

**Utility Name:** PG&E

**Phone Number:** [Redacted]

**Email Address:** [Redacted]

**Incident Location:** West Rose Street Between N Yosemite and N San Jose Streets Stockton, San Joaquin

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Tree/Line Contact (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Harding 0402
- Voltage (KV): 4
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** CPUC Electric Incident - EI231029A On December 27, 2023, PG&E Law Claims was notified of a customer claim which will likely exceed \$50,000 in property damages. The claim involves a structure fire on West Rose Street, between North Yosemite Street and North San Jose Street, Stockton, San Joaquin County, a non-HFTD. The customer is served by the Harding 0402 4kV overhead circuit. The claim alleges that on October 29, 2023, at 11:39 am, PG&E facilities caused a fire in a tree behind the customer's home. The claim states that the fire spread to the customers home and destroyed it. This incident is being reported under the property damage criterion. This information is preliminary.